

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA				
										70				
<b>Target Air Quality Levels</b>														
<b>EPA Site Specific Trigger Levels</b>														
ASBESTOS-ST1-1/4/08	030800326-0001	Southwest Area (sidewalk bridge level)	1/4/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST2-1/4/08	030800326-0002	Southeast Area (sidewalk bridge level)	1/4/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST4-1/4/08	030800326-0003	Northwest Area (street-level)	1/4/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST5-1/4/08	030800326-0004	Firehouse #10 (roof level)	1/4/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST10-1/4/08	030800326-0005	North Side Sidewalk Bridge	1/4/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST100-1/4/08	030800326-0013	Station 10 Field Duplicate	1/4/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST11-1/4/08	030800326-0006	90 Trinity Place (roof level)	1/4/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST12-1/4/08	030800326-0007	110 Greenwich Street (roof level)	1/4/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST13-1/4/08	030800326-0008	Marriott Hotel, 38th Floor (roof level)	1/4/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST14-1/4/08	030800326-0009	West Face - South end at corner (scaffolding level)	1/4/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST15-1/4/08	030800326-0010	South Face - East end at corner (scaffolding level)	1/4/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST16-1/4/08	030800326-0011	East Face - North end at corner (scaffolding level)	1/4/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST17-1/4/08	030800326-0012	North Face - West end at corner (scaffolding level)	1/4/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST1-1/5/08	030800327-0001	Southwest Area (sidewalk bridge level)	1/5/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST2-1/5/08	030800327-0002	Southeast Area (sidewalk bridge level)	1/5/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST4-1/5/08	030800327-0003	Northwest Area (street-level)	1/5/08	1	3.340	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 15.00	No	No		
ASBESTOS-ST5-1/5/08	030800327-0004	Firehouse #10 (roof level)	1/5/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST10-1/5/08	030800327-0005	North Side Sidewalk Bridge	1/5/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 15.00	No	No		
ASBESTOS-ST11-1/5/08	030800327-0006	90 Trinity Place (roof level)	1/5/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 15.00	No	No		
ASBESTOS-ST12-1/5/08	030800327-0007	110 Greenwich Street (roof level)	1/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST13-1/5/08	030800327-0008	Marriott Hotel, 38th Floor (roof level)	1/5/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 15.00	No	No		
ASBESTOS-ST14-1/5/08	030800327-0009	West Face - South end at corner (scaffolding level)	1/5/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 13.00	No	No		
ASBESTOS-ST15-1/5/08	030800327-0010	South Face - East end at corner (scaffolding level)	1/5/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 15.00	No	No		
ASBESTOS-ST16-1/5/08	030800327-0011	East Face - North end at corner (scaffolding level)	1/5/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 15.00	No	No		
ASBESTOS-ST17-1/5/08	030800327-0012	North Face - West end at corner (scaffolding level)	1/5/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/6/08	< 15.00	No	No		
ASBESTOS-ST1-1/6/08	030800359-0001	Southwest Area (sidewalk bridge level)	1/6/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 15.00	No	No		
ASBESTOS-ST2-1/6/08	030800359-0002	Southeast Area (sidewalk bridge level)	1/6/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 13.00	No	No		
ASBESTOS-ST4-1/6/08	030800359-0003	Northwest Area (street-level)	1/6/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 15.00	No	No		
ASBESTOS-ST5-1/6/08	030800359-0004	Firehouse #10 (roof level)	1/6/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 15.00	No	No		
ASBESTOS-ST10-1/6/08	030800359-0005	North Side Sidewalk Bridge	1/6/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 15.00	No	No		
ASBESTOS-ST11-1/6/08	030800359-0006	90 Trinity Place (roof level)	1/6/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 15.00	No	No		
ASBESTOS-ST12-1/6/08	030800359-0007	110 Greenwich Street (roof level)	1/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 13.00	No	No		
ASBESTOS-ST13-1/6/08	030800359-0008	Marriott Hotel, 38th Floor (roof level)	1/6/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 15.00	No	No		
ASBESTOS-ST14-1/6/08	030800359-0009	West Face - South end at corner (scaffolding level)	1/6/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 13.00	No	No		
ASBESTOS-ST15-1/6/08	030800359-0010	South Face - East end at corner (scaffolding level)	1/6/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 13.00	No	No		
ASBESTOS-ST16-1/6/08	030800359-0011	East Face - North end at corner (scaffolding level)	1/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 13.00	No	No		
ASBESTOS-ST17-1/6/08	030800359-0012	North Face - West end at corner (scaffolding level)	1/6/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/7/08	< 15.00	No	No		
ASBESTOS-ST1-1/7/08	030800465-0001	Southwest Area (sidewalk bridge level)	1/7/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST2-1/7/08	030800465-0002	Southeast Area (sidewalk bridge level)	1/7/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST4-1/7/08	030800465-0003	Northwest Area (street-level)	1/7/08	1	3.340	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST5-1/7/08	030800465-0004	Firehouse #10 (roof level)	1/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST10-1/7/08	030800465-0005	North Side Sidewalk Bridge	1/7/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST11-1/7/08	030800465-0006	90 Trinity Place (roof level)	1/7/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST12-1/7/08	030800465-0007	110 Greenwich Street (roof level)	1/7/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST13-1/7/08	030800465-0008	Marriott Hotel, 38th Floor (roof level)	1/7/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST14-1/7/08	030800465-0009	West Face - South end at corner (scaffolding level)	1/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST15-1/7/08	030800465-0010	South Face - East end at corner (scaffolding level)	1/7/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST16-1/7/08	030800465-0011	East Face - North end at corner (scaffolding level)	1/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		
ASBESTOS-ST17-1/7/08	030800465-0012	North Face - West end at corner (scaffolding level)	1/7/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/8/08	< 13.00	No	No		