

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality	Exceeds EPA	
										70	Levels	Site Specific	
												Trigger Levels	
ASBESTOS-ST1-1/8/08	030800551-0001	Southwest Area (sidewalk bridge level)	1/8/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST2-1/8/08	030800551-0002	Southeast Area (sidewalk bridge level)	1/8/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST4-1/8/08	030800551-0003	Northwest Area (street-level)	1/8/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST5-1/8/08	030800551-0004	Firehouse #10 (roof level)	1/8/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST10-1/8/08	030800551-0005	North Side Sidewalk Bridge	1/8/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST11-1/8/08	030800551-0006	90 Trinity Place (roof level)	1/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST12-1/8/08	030800551-0007	110 Greenwich Street (roof level)	1/8/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST13-1/8/08	030800551-0008	Marriott Hotel, 38th Floor (roof level)	1/8/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST14-1/8/08	030800551-0009	West Face - South end at corner (scaffolding level)	1/8/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST15-1/8/08	030800551-0010	South Face - East end at corner (scaffolding level)	1/8/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST16-1/8/08	030800551-0011	East Face - North end at corner (scaffolding level)	1/8/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST17-1/8/08	030800551-0012	North Face - West end at corner (scaffolding level)	1/8/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/9/08	< 13.00	No	No	
ASBESTOS-ST1-1/9/08	030800659-0001	Southwest Area (sidewalk bridge level)	1/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 13.00	No	No	
ASBESTOS-ST2-1/9/08	030800659-0002	Southeast Area (sidewalk bridge level)	1/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 13.00	No	No	
ASBESTOS-ST4-1/9/08	030800659-0003	Northwest Area (street-level)	1/9/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 15.00	No	No	
ASBESTOS-ST5-1/9/08	030800659-0004	Firehouse #10 (roof level)	1/9/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 15.00	No	No	
ASBESTOS-ST10-1/9/08	030800659-0005	North Side Sidewalk Bridge	1/9/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 15.00	No	No	
ASBESTOS-ST11-1/9/08	030800659-0006	90 Trinity Place (roof level)	1/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 13.00	No	No	
ASBESTOS-ST12-1/9/08	030800659-0007	110 Greenwich Street (roof level)	1/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 13.00	No	No	
ASBESTOS-ST13-1/9/08	030800659-0008	Marriott Hotel, 38th Floor (roof level)	1/9/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 13.00	No	No	
ASBESTOS-ST14-1/9/08	030800659-0009	West Face - South end at corner (scaffolding level)	1/9/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 15.00	No	No	
ASBESTOS-ST15-1/9/08	030800659-0010	South Face - East end at corner (scaffolding level)	1/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 13.00	No	No	
ASBESTOS-ST16-1/9/08	030800659-0011	East Face - North end at corner (scaffolding level)	1/9/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 15.00	No	No	
ASBESTOS-ST17-1/9/08	030800659-0012	North Face - West end at corner (scaffolding level)	1/9/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/10/08	< 15.00	No	No	