

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-1/10/06	030600939-0001	Southwest Area (sidewalk bridge level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST2-1/10/06	030600939-0002	Southeast Area (sidewalk bridge level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST4-1/10/06	030600939-0003	Northwest Area (street-level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST5-1/10/06	030600939-0004	Firehouse #10 (roof level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST10-1/10/06	030600939-0005	North Side Sidewalk Bridge	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST11-1/10/06	030600939-0006	90 Trinity Place (roof level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST12-1/10/06	030600939-0007	110 Greenwich Street (roof level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST13-1/10/06	030600939-0008	Marriott Hotel, 38th Floor (roof level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST14-1/10/06	030600939-0009	West Face - South end at corner (scaffolding level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST15-1/10/06	030600939-0010	South Face - East end at corner (scaffolding level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST16-1/10/06	030600939-0011	East Face - North end at corner (scaffolding level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST17-1/10/06	030600939-0012	North Face - West end at corner (scaffolding level)	1/10/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/06	< 13.00	No	No	
ASBESTOS-ST1-1/11/06	030601087-0001	Southwest Area (sidewalk bridge level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST2-1/11/06	030601087-0002	Southeast Area (sidewalk bridge level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST4-1/11/06	030601087-0003	Northwest Area (street-level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST5-1/11/06	030601087-0004	Firehouse #10 (roof level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST10-1/11/06	030601087-0005	North Side Sidewalk Bridge	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST11-1/11/06	030601087-0006	90 Trinity Place (roof level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST12-1/11/06	030601087-0007	110 Greenwich Street (roof level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST13-1/11/06	030601087-0008	Marriott Hotel, 38th Floor (roof level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST14-1/11/06	030601087-0009	West Face - South end at corner (scaffolding level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST15-1/11/06	030601087-0010	South Face - East end at corner (scaffolding level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST16-1/11/06	030601087-0011	East Face - North end at corner (scaffolding level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	
ASBESTOS-ST17-1/11/06	030601087-0012	North Face - West end at corner (scaffolding level)	1/11/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/06	< 13.00	No	No	