

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-1/10/07	030701053-0001	Southwest Area (sidewalk bridge level)	1/10/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST2-1/10/07	030701053-0002	Southeast Area (sidewalk bridge level)	1/10/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST4-1/10/07	030701053-0003	Northwest Area (street-level)	1/10/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST5-1/10/07	030701053-0004	Firehouse #10 (roof level)	1/10/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST10-1/10/07	030701053-0005	North Side Sidewalk Bridge	1/10/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST11-1/10/07	030701053-0006	90 Trinity Place (roof level)	1/10/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST12-1/10/07	030701053-0007	110 Greenwich Street (roof level)	1/10/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST13-1/10/07	030701053-0008	Marriott Hotel, 38th Floor (roof level)	1/10/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST14-1/10/07	030701053-0009	West Face - South end at corner (scaffolding level)	1/10/07	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST15-1/10/07	030701053-0010	South Face - East end at corner (scaffolding level)	1/10/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST16-1/10/07	030701053-0011	East Face - North end at corner (scaffolding level)	1/10/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST17-1/10/07	030701053-0012	North Face - West end at corner (scaffolding level)	1/10/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/11/07	< 13.00	No	No	
ASBESTOS-ST1-1/11/07	030701146-0001	Southwest Area (sidewalk bridge level)	1/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST2-1/11/07	030701146-0002	Southeast Area (sidewalk bridge level)	1/11/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST4-1/11/07	030701146-0003	Northwest Area (street-level)	1/11/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST5-1/11/07	030701146-0004	Firehouse #10 (roof level)	1/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST10-1/11/07	030701146-0005	North Side Sidewalk Bridge	1/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST11-1/11/07	030701146-0006	90 Trinity Place (roof level)	1/11/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST12-1/11/07	030701146-0007	110 Greenwich Street (roof level)	1/11/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST13-1/11/07	030701146-0008	Marriott Hotel, 38th Floor (roof level)	1/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST14-1/11/07	030701146-0009	West Face - South end at corner (scaffolding level)	1/11/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST15-1/11/07	030701146-0010	South Face - East end at corner (scaffolding level)	1/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST16-1/11/07	030701146-0011	East Face - North end at corner (scaffolding level)	1/11/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	
ASBESTOS-ST17-1/11/07	030701146-0012	North Face - West end at corner (scaffolding level)	1/11/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/12/07	< 13.00	No	No	