

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-1/17/07	030701751-0001	Southwest Area (sidewalk bridge level)	1/17/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST2-1/17/07	030701751-0002	Southeast Area (sidewalk bridge level)	1/17/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST4-1/17/07	030701751-0003	Northwest Area (street-level)	1/17/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST5-1/17/07	030701751-0004	Firehouse #10 (roof level)	1/17/07	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST10-1/17/07	030701751-0005	North Side Sidewalk Bridge	1/17/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST11-1/17/07	030701751-0006	90 Trinity Place (roof level)	1/17/07	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST12-1/17/07	030701751-0007	110 Greenwich Street (roof level)	1/17/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST13-1/17/07	030701751-0008	Marriott Hotel, 38th Floor (roof level)	1/17/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST14-1/17/07	030701751-0009	West Face - South end at corner (scaffolding level)	1/17/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST15-1/17/07	030701751-0010	South Face - East end at corner (scaffolding level)	1/17/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST16-1/17/07	030701751-0011	East Face - North end at corner (scaffolding level)	1/17/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST17-1/17/07	030701751-0012	North Face - West end at corner (scaffolding level)	1/17/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/18/07	< 13.00	No	No	
ASBESTOS-ST1-1/18/07	030701893-0001	Southwest Area (sidewalk bridge level)	1/18/07	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST2-1/18/07	030701893-0002	Southeast Area (sidewalk bridge level)	1/18/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST4-1/18/07	030701893-0003	Northwest Area (street-level)	1/18/07	1	3.400	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	Note 1
ASBESTOS-ST5-1/18/07	030701893-0004	Firehouse #10 (roof level)	1/18/07	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST10-1/18/07	030701893-0005	North Side Sidewalk Bridge	1/18/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST11-1/18/07	030701893-0006	90 Trinity Place (roof level)	1/18/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST12-1/18/07	030701893-0007	110 Greenwich Street (roof level)	1/18/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST13-1/18/07	030701893-0008	Marriott Hotel, 38th Floor (roof level)	1/18/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST14-1/18/07	030701893-0009	West Face - South end at corner (scaffolding level)	1/18/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST15-1/18/07	030701893-0010	South Face - East end at corner (scaffolding level)	1/18/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST16-1/18/07	030701893-0011	East Face - North end at corner (scaffolding level)	1/18/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	
ASBESTOS-ST17-1/18/07	030701893-0012	North Face - West end at corner (scaffolding level)	1/18/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/19/07	< 13.00	No	No	

Note:

1. Due to flow rate RPD exceedance (21.9%) for asbestos at Station 4 (Northwest Area [street-level]) on January 18, 2007, the sample volume and subsequent sample result are estimated.