

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)			Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA					
										70					
Target Air Quality Levels															
EPA Site Specific Trigger Levels															
ASBESTOS-ST1-1/21/08	030801791-0001	Southwest Area (sidewalk bridge level)	1/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST2-1/21/08	030801791-0002	Southeast Area (sidewalk bridge level)	1/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST4-1/21/08	030801791-0003	Northwest Area (street-level)	1/21/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST5-1/21/08	030801791-0004	Firehouse #10 (roof level)	1/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST10-1/21/08	030801791-0005	North Side Sidewalk Bridge	1/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 15.00	No	No			
ASBESTOS-ST11-1/21/08	030801791-0006	90 Trinity Place (roof level)	1/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 15.00	No	No			
ASBESTOS-ST12-1/21/08	030801791-0007	110 Greenwich Street (roof level)	1/21/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST13-1/21/08	030801791-0008	Marriott Hotel, 38th Floor (roof level)	1/21/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST14-1/21/08	030801791-0009	West Face - South end at corner (scaffolding level)	1/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST15-1/21/08	030801791-0010	South Face - East end at corner (scaffolding level)	1/21/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST16-1/21/08	030801791-0011	East Face - North end at corner (scaffolding level)	1/21/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 13.00	No	No			
ASBESTOS-ST17-1/21/08	030801791-0012	North Face - West end at corner (scaffolding level)	1/21/08	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/22/08	< 15.00	No	No			
ASBESTOS-ST1-1/22/08	030801891-0001	Southwest Area (sidewalk bridge level)	1/22/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 13.00	No	No			
ASBESTOS-ST2-1/22/08	030801891-0002	Southeast Area (sidewalk bridge level)	1/22/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 15.00	No	No			
ASBESTOS-ST4-1/22/08	030801891-0003	Northwest Area (street-level)	1/22/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 13.00	No	No			
ASBESTOS-ST5-1/22/08	030801891-0004	Firehouse #10 (roof level)	1/22/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 15.00	No	No			
ASBESTOS-ST10-1/22/08	030801891-0005	North Side Sidewalk Bridge	1/22/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 13.00	No	No			
ASBESTOS-ST100-1/22/08	030801891-0013	Station 10 Field Duplicate	1/22/08	1	3.370	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 15.00	No	No			
ASBESTOS-ST11-1/22/08	030801891-0006	90 Trinity Place (roof level)	1/22/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 15.00	No	No			
ASBESTOS-ST12-1/22/08	030801891-0007	110 Greenwich Street (roof level)	1/22/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 13.00	No	No			
ASBESTOS-ST13-1/22/08	030801891-0008	Marriott Hotel, 38th Floor (roof level)	1/22/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 15.00	No	No			
ASBESTOS-ST14-1/22/08	030801891-0009	West Face - South end at corner (scaffolding level)	1/22/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 13.00	No	No			
ASBESTOS-ST15-1/22/08	030801891-0010	South Face - East end at corner (scaffolding level)	1/22/08	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 13.00	No	No			
ASBESTOS-ST16-1/22/08	030801891-0011	East Face - North end at corner (scaffolding level)	1/22/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 15.00	No	No			
ASBESTOS-ST17-1/22/08	030801891-0012	North Face - West end at corner (scaffolding level)	1/22/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/08	< 15.00	No	No			
ASBESTOS-ST1-1/23/08	030802032-0001	Southwest Area (sidewalk bridge level)	1/23/08	1	2.910	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST2-1/23/08	030802032-0002	Southeast Area (sidewalk bridge level)	1/23/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST4-1/23/08	030802032-0003	Northwest Area (street-level)	1/23/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST5-1/23/08	030802032-0004	Firehouse #10 (roof level)	1/23/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST10-1/23/08	030802032-0005	North Side Sidewalk Bridge	1/23/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST11-1/23/08	030802032-0006	90 Trinity Place (roof level)	1/23/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST12-1/23/08	030802032-0007	110 Greenwich Street (roof level)	1/23/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST13-1/23/08	030802032-0008	Marriott Hotel, 38th Floor (roof level)	1/23/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST14-1/23/08	030802032-0009	West Face - South end at corner (scaffolding level)	1/23/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST15-1/23/08	030802032-0010	South Face - East end at corner (scaffolding level)	1/23/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST16-1/23/08	030802032-0011	East Face - North end at corner (scaffolding level)	1/23/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			
ASBESTOS-ST17-1/23/08	030802032-0012	North Face - West end at corner (scaffolding level)	1/23/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/08	< 13.00	No	No			