

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
<b>Target Air Quality Levels</b>										<b>NA</b>			
<b>EPA Site Specific Trigger Levels</b>										<b>70</b>			
ASBESTOS-ST1-1/22/07	030702216-0001	Southwest Area (sidewalk bridge level)	1/22/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST2-1/22/07	030702216-0002	Southeast Area (sidewalk bridge level)	1/22/07	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST4-1/22/07	030702216-0003	Northwest Area (street-level)	1/22/07	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST5-1/22/07	030702216-0004	Firehouse #10 (roof level)	1/22/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST10-1/22/07	030702216-0005	North Side Sidewalk Bridge	1/22/07	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST11-1/22/07	030702216-0006	90 Trinity Place (roof level)	1/22/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST12-1/22/07	030702216-0007	110 Greenwich Street (roof level)	1/22/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST13-1/22/07	030702216-0008	Marriott Hotel, 38th Floor (roof level)	1/22/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST14-1/22/07	030702216-0009	West Face - South end at corner (scaffolding level)	1/22/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST15-1/22/07	030702216-0010	South Face - East end at corner (scaffolding level)	1/22/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST16-1/22/07	030702216-0011	East Face - North end at corner (scaffolding level)	1/22/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST17-1/22/07	030702216-0012	North Face - West end at corner (scaffolding level)	1/22/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/23/07	< 13.00	No	No	
ASBESTOS-ST1-1/23/07	030702383-0001	Southwest Area (sidewalk bridge level)	1/23/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 15.00	No	No	
ASBESTOS-ST2-1/23/07	030702383-0002	Southeast Area (sidewalk bridge level)	1/23/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 13.00	No	No	
ASBESTOS-ST4-1/23/07	030702383-0003	Northwest Area (street-level)	1/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 13.00	No	No	
ASBESTOS-ST5-1/23/07	030702383-0004	Firehouse #10 (roof level)	1/23/07	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 13.00	No	No	
ASBESTOS-ST10-1/23/07	030702383-0005	North Side Sidewalk Bridge	1/23/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 15.00	No	No	
ASBESTOS-ST100-1/23/07	030702383-0013	Station 10 Field Duplicate	1/23/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 13.00	No	No	
ASBESTOS-ST11-1/23/07	030702383-0006	90 Trinity Place (roof level)	1/23/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 15.00	No	No	
ASBESTOS-ST12-1/23/07	030702383-0007	110 Greenwich Street (roof level)	1/23/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 13.00	No	No	
ASBESTOS-ST13-1/23/07	030702383-0008	Marriott Hotel, 38th Floor (roof level)	1/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 13.00	No	No	
ASBESTOS-ST14-1/23/07	030702383-0009	West Face - South end at corner (scaffolding level)	1/23/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 15.00	No	No	
ASBESTOS-ST15-1/23/07	030702383-0010	South Face - East end at corner (scaffolding level)	1/23/07	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 15.00	No	No	
ASBESTOS-ST16-1/23/07	030702383-0011	East Face - North end at corner (scaffolding level)	1/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 13.00	No	No	
ASBESTOS-ST17-1/23/07	030702383-0012	North Face - West end at corner (scaffolding level)	1/23/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/24/07	< 15.00	No	No	