

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
<b>Target Air Quality Levels</b>													
<b>EPA Site Specific Trigger Levels</b>													
ASBESTOS-ST1-2/14/06	030604709-0001	Southwest Area (sidewalk bridge level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST2-2/14/06	030604709-0002	Southeast Area (sidewalk bridge level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST4-2/14/06	030604709-0003	Northwest Area (street-level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST5-2/14/06	030604709-0004	Firehouse #10 (roof level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST10-2/14/06	030604709-0005	North Side Sidewalk Bridge	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST11-2/14/06	030604709-0006	90 Trinity Place (roof level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST12-2/14/06	030604709-0007	110 Greenwich Street (roof level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST13-2/14/06	030604709-0008	Marriott Hotel, 38th Floor (roof level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST14-2/14/06	030604709-0009	West Face - South end at corner (scaffolding level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST15-2/14/06	030604709-0010	South Face - East end at corner (scaffolding level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST16-2/14/06	030604709-0011	East Face - North end at corner (scaffolding level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST17-2/14/06	030604709-0012	North Face - West end at corner (scaffolding level)	2/14/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/15/06	< 13.00	No	No	
ASBESTOS-ST1-2/15/06	030604867-0001	Southwest Area (sidewalk bridge level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST2-2/15/06	030604867-0002	Southeast Area (sidewalk bridge level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST4-2/15/06	030604867-0003	Northwest Area (street-level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST5-2/15/06	030604867-0004	Firehouse #10 (roof level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST10-2/15/06	030604867-0005	North Side Sidewalk Bridge	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST11-2/15/06	030604867-0006	90 Trinity Place (roof level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST12-2/15/06	030604867-0007	110 Greenwich Street (roof level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST13-2/15/06	030604867-0008	Marriott Hotel, 38th Floor (roof level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST14-2/15/06	030604867-0009	West Face - South end at corner (scaffolding level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST15-2/15/06	030604867-0010	South Face - East end at corner (scaffolding level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST16-2/15/06	030604867-0011	East Face - North end at corner (scaffolding level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	
ASBESTOS-ST17-2/15/06	030604867-0012	North Face - West end at corner (scaffolding level)	2/15/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/16/06	< 13.00	No	No	