

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-2/21/07	030705506-0001	Southwest Area (sidewalk bridge level)	2/21/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/22/07	< 13.00	No	No	
ASBESTOS-ST2-2/21/07	030705506-0002	Southeast Area (sidewalk bridge level)	2/21/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/22/07	< 13.00	No	No	
ASBESTOS-ST4-2/21/07	030705506-0003	Northwest Area (street-level)	2/21/07	1	3.330	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/22/07	< 13.00	No	No	
ASBESTOS-ST5-2/21/07	030705506-0004	Firehouse #10 (roof level)	2/21/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/22/07	< 13.00	No	No	
ASBESTOS-ST10-2/21/07	030705506-0005	North Side Sidewalk Bridge	2/21/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/22/07	< 13.00	No	No	
ASBESTOS-ST11-2/21/07	030705506-0006	90 Trinity Place (roof level)	2/21/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/22/07	< 13.00	No	No	
ASBESTOS-ST12-2/21/07	030705506-0007	110 Greenwich Street (roof level)	2/21/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/22/07	< 13.00	No	No	
ASBESTOS-ST13-2/21/07	030705506-0008	Marriott Hotel, 38th Floor (roof level)	2/21/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/22/07	< 13.00	No	No	
ASBESTOS-ST1-2/22/07	030705670-0001	Southwest Area (sidewalk bridge level)	2/22/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST2-2/22/07	030705670-0002	Southeast Area (sidewalk bridge level)	2/22/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST4-2/22/07	030705670-0003	Northwest Area (street-level)	2/22/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST5-2/22/07	030705670-0004	Firehouse #10 (roof level)	2/22/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST10-2/22/07	030705670-0005	North Side Sidewalk Bridge	2/22/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST11-2/22/07	030705670-0006	90 Trinity Place (roof level)	2/22/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST12-2/22/07	030705670-0007	110 Greenwich Street (roof level)	2/22/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST13-2/22/07	030705670-0008	Marriott Hotel, 38th Floor (roof level)	2/22/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST14-2/22/07	030705670-0009	West Face - South end at corner (scaffolding level)	2/22/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST15-2/22/07	030705670-0010	South Face - East end at corner (scaffolding level)	2/22/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST16-2/22/07	030705670-0011	East Face - North end at corner (scaffolding level)	2/22/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	
ASBESTOS-ST17-2/22/07	030705670-0012	North Face - West end at corner (scaffolding level)	2/22/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	2/23/07	< 13.00	No	No	

Note:
1. Asbestos samples at Station 14 (West Face - South end at corner [scaffolding level]), Station 15 (South Face - East end at corner [scaffolding level]), Station 16 (East Face - North end at corner [scaffolding level]), and Station 17 (North Face - West end at corner [scaffolding level]) on February 21, 2007 were not available for analysis on account of power failure.