

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	Comments
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-3/6/08	030805957-0001	Southwest Area (sidewalk bridge level)	3/6/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST2-3/6/08	030805957-0002	Southeast Area (sidewalk bridge level)	3/6/08	1	2.790	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST4-3/6/08	030805957-0003	Northwest Area (street-level)	3/6/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST5-3/6/08	030805957-0004	Firehouse #10 (roof level)	3/6/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST10-3/6/08	030805957-0005	North Side Sidewalk Bridge	3/6/08	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST11-3/6/08	030805957-0006	90 Trinity Place (roof level)	3/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST12-3/6/08	030805957-0007	110 Greenwich Street (roof level)	3/6/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST13-3/6/08	030805957-0008	Marriott Hotel, 38th Floor (roof level)	3/6/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST14-3/6/08	030805957-0009	West Face - South end at corner (scaffolding level)	3/6/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST15-3/6/08	030805957-0010	South Face - East end at corner (scaffolding level)	3/6/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST16-3/6/08	030805957-0011	East Face - North end at corner (scaffolding level)	3/6/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST17-3/6/08	030805957-0012	North Face - West end at corner (scaffolding level)	3/6/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/7/08	< 13.00	No	No		
ASBESTOS-ST1-3/7/08	030806046-0001	Southwest Area (sidewalk bridge level)	3/7/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 15.00	No	No		
ASBESTOS-ST2-3/7/08	030806046-0002	Southeast Area (sidewalk bridge level)	3/7/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 15.00	No	No		
ASBESTOS-ST4-3/7/08	030806046-0003	Northwest Area (street-level)	3/7/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 13.00	No	No		
ASBESTOS-ST5-3/7/08	030806046-0004	Firehouse #10 (roof level)	3/7/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 15.00	No	No		
ASBESTOS-ST10-3/7/08	030806046-0005	North Side Sidewalk Bridge	3/7/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 15.00	No	No		
ASBESTOS-ST11-3/7/08	030806046-0006	90 Trinity Place (roof level)	3/7/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 13.00	No	No		
ASBESTOS-ST12-3/7/08	030806046-0007	110 Greenwich Street (roof level)	3/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 13.00	No	No		
ASBESTOS-ST13-3/7/08	030806046-0008	Marriott Hotel, 38th Floor (roof level)	3/7/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 13.00	No	No		
ASBESTOS-ST14-3/7/08	030806046-0009	West Face - South end at corner (scaffolding level)	3/7/08	1	3.250	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 15.00	No	No		
ASBESTOS-ST15-3/7/08	030806046-0010	South Face - East end at corner (scaffolding level)	3/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 13.00	No	No		
ASBESTOS-ST16-3/7/08	030806046-0011	East Face - North end at corner (scaffolding level)	3/7/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 13.00	No	No		
ASBESTOS-ST17-3/7/08	030806046-0012	North Face - West end at corner (scaffolding level)	3/7/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/8/08	< 13.00	No	No		
ASBESTOS-ST1-3/8/08	030806266-0001	Southwest Area (sidewalk bridge level)	3/8/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST2-3/8/08	030806266-0002	Southeast Area (sidewalk bridge level)	3/8/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST4-3/8/08	030806266-0003	Northwest Area (street-level)	3/8/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST5-3/8/08	030806266-0004	Firehouse #10 (roof level)	3/8/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST10-3/8/08	030806266-0005	North Side Sidewalk Bridge	3/8/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST11-3/8/08	030806266-0006	90 Trinity Place (roof level)	3/8/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST12-3/8/08	030806266-0007	110 Greenwich Street (roof level)	3/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST13-3/8/08	030806266-0008	Marriott Hotel, 38th Floor (roof level)	3/8/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST14-3/8/08	030806266-0009	West Face - South end at corner (scaffolding level)	3/8/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST15-3/8/08	030806266-0010	South Face - East end at corner (scaffolding level)	3/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST16-3/8/08	030806266-0011	East Face - North end at corner (scaffolding level)	3/8/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST17-3/8/08	030806266-0012	North Face - West end at corner (scaffolding level)	3/8/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST1-3/9/08	030806229-0001	Southwest Area (sidewalk bridge level)	3/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST2-3/9/08	030806229-0002	Southeast Area (sidewalk bridge level)	3/9/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 15.00	No	No		
ASBESTOS-ST4-3/9/08	030806229-0003	Northwest Area (street-level)	3/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST5-3/9/08	030806229-0004	Firehouse #10 (roof level)	3/9/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 15.00	No	No		
ASBESTOS-ST10-3/9/08	030806229-0005	North Side Sidewalk Bridge	3/9/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST11-3/9/08	030806229-0006	90 Trinity Place (roof level)	3/9/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST12-3/9/08	030806229-0007	110 Greenwich Street (roof level)	3/9/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST13-3/9/08	030806229-0008	Marriott Hotel, 38th Floor (roof level)	3/9/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST14-3/9/08	030806229-0009	West Face - South end at corner (scaffolding level)	3/9/08	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		
ASBESTOS-ST15-3/9/08	030806229-0010	South Face - East end at corner (scaffolding level)	3/9/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No	Note 1	
ASBESTOS-ST16-3/9/08	030806229-0011	East Face - North end at corner (scaffolding level)	3/9/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 15.00	No	No		
ASBESTOS-ST17-3/9/08	030806229-0012	North Face - West end at corner (scaffolding level)	3/9/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	3/10/08	< 13.00	No	No		

Note:

1. Due to a flow rate RPD exceedance (48.1%) for asbestos at Station 15 (South Face - East end at corner [scaffolding level]) on March 9, 2008, the sample volume and subsequent sample result are estimated.