

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-3/31/08	030809212-0001	Southwest Area (sidewalk bridge level)	3/31/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST2-3/31/08	030809212-0002	Southeast Area (sidewalk bridge level)	3/31/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST4-3/31/08	030809212-0003	Northwest Area (street-level)	3/31/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST5-3/31/08	030809212-0004	Firehouse #10 (roof level)	3/31/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST10-3/31/08	030809212-0005	North Side Sidewalk Bridge	3/31/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST11-3/31/08	030809212-0006	90 Trinity Place (roof level)	3/31/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST12-3/31/08	030809212-0007	110 Greenwich Street (roof level)	3/31/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST13-3/31/08	030809212-0008	Marriott Hotel, 38th Floor (roof level)	3/31/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST14-3/31/08	030809212-0009	West Face - South end at corner (scaffolding level)	3/31/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST15-3/31/08	030809212-0010	South Face - East end at corner (scaffolding level)	3/31/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST16-3/31/08	030809212-0011	East Face - North end at corner (scaffolding level)	3/31/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST17-3/31/08	030809212-0012	North Face - West end at corner (scaffolding level)	3/31/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/1/08	< 13.00	No	No	
ASBESTOS-ST1-4/1/08	030809339-0001	Southwest Area (sidewalk bridge level)	4/1/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST2-4/1/08	030809339-0002	Southeast Area (sidewalk bridge level)	4/1/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST4-4/1/08	030809339-0003	Northwest Area (street-level)	4/1/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST5-4/1/08	030809339-0004	Firehouse #10 (roof level)	4/1/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST10-4/1/08	030809339-0005	North Side Sidewalk Bridge	4/1/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST11-4/1/08	030809339-0006	90 Trinity Place (roof level)	4/1/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST12-4/1/08	030809339-0007	110 Greenwich Street (roof level)	4/1/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST13-4/1/08	030809339-0008	Marriott Hotel, 38th Floor (roof level)	4/1/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST14-4/1/08	030809339-0009	West Face - South end at corner (scaffolding level)	4/1/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST15-4/1/08	030809339-0010	South Face - East end at corner (scaffolding level)	4/1/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST16-4/1/08	030809339-0011	East Face - North end at corner (scaffolding level)	4/1/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	
ASBESTOS-ST17-4/1/08	030809339-0012	North Face - West end at corner (scaffolding level)	4/1/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/2/08	< 13.00	No	No	