

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels											70	Levels	Trigger Levels	
ASBESTOS-ST1-4/2/07	030710264-0001	Southwest Area (sidewalk bridge level)	4/2/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST2-4/2/07	030710264-0002	Southeast Area (sidewalk bridge level)	4/2/07	1	3.220	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST4-4/2/07	030710264-0003	Northwest Area (street-level)	4/2/07	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST5-4/2/07	030710264-0004	Firehouse #10 (roof level)	4/2/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST10-4/2/07	030710264-0005	North Side Sidewalk Bridge	4/2/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST11-4/2/07	030710264-0006	90 Trinity Place (roof level)	4/2/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST12-4/2/07	030710264-0007	110 Greenwich Street (roof level)	4/2/07	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST13-4/2/07	030710264-0008	Marriott Hotel, 38th Floor (roof level)	4/2/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST14-4/2/07	030710264-0009	West Face - South end at corner (scaffolding level)	4/2/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST15-4/2/07	030710264-0010	South Face - East end at corner (scaffolding level)	4/2/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST16-4/2/07	030710264-0011	East Face - North end at corner (scaffolding level)	4/2/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST17-4/2/07	030710264-0012	North Face - West end at corner (scaffolding level)	4/2/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/3/07	< 13.00	No	No		
ASBESTOS-ST1-4/3/07	030710396-0001	Southwest Area (sidewalk bridge level)	4/3/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST2-4/3/07	030710396-0002	Southeast Area (sidewalk bridge level)	4/3/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST4-4/3/07	030710396-0003	Northwest Area (street-level)	4/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST5-4/3/07	030710396-0004	Firehouse #10 (roof level)	4/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST10-4/3/07	030710396-0005	North Side Sidewalk Bridge	4/3/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST100-4/3/07	030710396-0013	Station 10 Field Duplicate	4/3/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST11-4/3/07	030710396-0006	90 Trinity Place (roof level)	4/3/07	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST12-4/3/07	030710396-0007	110 Greenwich Street (roof level)	4/3/07	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST13-4/3/07	030710396-0008	Marriott Hotel, 38th Floor (roof level)	4/3/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST14-4/3/07	030710396-0009	West Face - South end at corner (scaffolding level)	4/3/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST15-4/3/07	030710396-0010	South Face - East end at corner (scaffolding level)	4/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST16-4/3/07	030710396-0011	East Face - North end at corner (scaffolding level)	4/3/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST17-4/3/07	030710396-0012	North Face - West end at corner (scaffolding level)	4/3/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/4/07	< 13.00	No	No		
ASBESTOS-ST1-4/04/07	030710496-0001	Southwest Area (sidewalk bridge level)	4/4/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST2-4/04/07	030710496-0002	Southeast Area (sidewalk bridge level)	4/4/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST4-4/04/07	030710496-0003	Northwest Area (street-level)	4/4/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST5-4/04/07	030710496-0004	Firehouse #10 (roof level)	4/4/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST10-4/04/07	030710496-0005	North Side Sidewalk Bridge	4/4/07	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST11-4/04/07	030710496-0006	90 Trinity Place (roof level)	4/4/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST12-4/04/07	030710496-0007	110 Greenwich Street (roof level)	4/4/07	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST13-4/04/07	030710496-0008	Marriott Hotel, 38th Floor (roof level)	4/4/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST14-4/04/07	030710496-0009	West Face - South end at corner (scaffolding level)	4/4/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST15-4/04/07	030710496-0010	South Face - East end at corner (scaffolding level)	4/4/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST16-4/04/07	030710496-0011	East Face - North end at corner (scaffolding level)	4/4/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		
ASBESTOS-ST17-4/04/07	030710496-0012	North Face - West end at corner (scaffolding level)	4/4/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/5/07	< 13.00	No	No		