

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
ASBESTOS-ST1-4/4/09	030908714-0001	Southwest Area (sidewalk bridge level)	4/4/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST2-4/4/09	030908714-0002	Southeast Area (sidewalk bridge level)	4/4/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST4-4/4/09	030908714-0003	Northwest Area (street-level)	4/4/09	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST5-4/4/09	030908714-0004	Firehouse #10 (roof level)	4/4/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST10-4/4/09	030908714-0005	North Side Sidewalk Bridge	4/4/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST11-4/4/09	030908714-0006	90 Trinity Place (roof level)	4/4/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST12-4/4/09	030908714-0007	110 Greenwich Street (roof level)	4/4/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST13-4/4/09	030908714-0008	Marriott Hotel, 38th Floor (roof level)	4/4/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST14-4/4/09	030908714-0009	West Face - South end at corner (scaffolding level)	4/4/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST15-4/4/09	030908714-0010	South Face - East end at corner (scaffolding level)	4/4/09	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST16-4/4/09	030908714-0011	East Face - North end at corner (scaffolding level)	4/4/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST17-4/4/09	030908714-0012	North Face - West end at corner (scaffolding level)	4/4/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST1-4/5/09	030908711-0001	Southwest Area (sidewalk bridge level)	4/5/09	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST4-4/5/09	030908711-0002	Northwest Area (street-level)	4/5/09	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST5-4/5/09	030908711-0003	Firehouse #10 (roof level)	4/5/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST10-4/5/09	030908711-0004	North Side Sidewalk Bridge	4/5/09	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST11-4/5/09	030908711-0005	90 Trinity Place (roof level)	4/5/09	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST12-4/5/09	030908711-0006	110 Greenwich Street (roof level)	4/5/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST13-4/5/09	030908711-0007	Marriott Hotel, 38th Floor (roof level)	4/5/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 13.00	No	No	
ASBESTOS-ST14-4/5/09	030908711-0008	West Face - South end at corner (scaffolding level)	4/5/09	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST15-4/5/09	030908711-0009	South Face - East end at corner (scaffolding level)	4/5/09	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST16-4/5/09	030908711-0010	East Face - North end at corner (scaffolding level)	4/5/09	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	
ASBESTOS-ST17-4/5/09	030908711-0011	North Face - West end at corner (scaffolding level)	4/5/09	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/6/09	< 15.00	No	No	

Note:

- The asbestos sample from Station 2 (Southeast Area [sidewalk bridge level]) on April 5, 2009 was not available for analysis on account of power failure.