

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA			
										70			
ASBESTOS-ST1-4/20/06	030612087-0001	Southwest Area (sidewalk bridge level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST2-4/20/06	030612087-0002	Southeast Area (sidewalk bridge level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST4-4/20/06	030612087-0003	Northwest Area (street-level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST5-4/20/06	030612087-0004	Firehouse #10 (roof level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST10-4/20/06	030612087-0005	North Side Sidewalk Bridge	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST100-4/20/06	030612087-0013	Station 10 Field Duplicate	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST11-4/20/06	030612087-0006	90 Trinity Place (roof level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST12-4/20/06	030612087-0007	110 Greenwich Street (roof level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST13-4/20/06	030612087-0008	Marriott Hotel, 38th Floor (roof level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST14-4/20/06	030612087-0009	West Face - South end at corner (scaffolding level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST15-4/20/06	030612087-0010	South Face - East end at corner (scaffolding level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	
ASBESTOS-ST17-4/20/06	030612087-0012	North Face - West end at corner (scaffolding level)	4/20/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/21/06	< 13.00	No	No	

Note:

- Asbestos sample at Station 16 (East Face - North end at corner [scaffolding level]) on April 20, 2006 was not available for analysis on account of a damaged filter.