

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-4/21/08	030811878-0001	Southwest Area (sidewalk bridge level)	4/21/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST2-4/21/08	030811878-0002	Southeast Area (sidewalk bridge level)	4/21/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST4-4/21/08	030811878-0003	Northwest Area (street-level)	4/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST5-4/21/08	030811878-0004	Firehouse #10 (roof level)	4/21/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST10-4/21/08	030811878-0005	North Side Sidewalk Bridge	4/21/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST11-4/21/08	030811878-0006	90 Trinity Place (roof level)	4/21/08	1	2.630	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST12-4/21/08	030811878-0007	110 Greenwich Street (roof level)	4/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST13-4/21/08	030811878-0008	Marriott Hotel, 38th Floor (roof level)	4/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST14-4/21/08	030811878-0009	West Face - South end at corner (scaffolding level)	4/21/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST15-4/21/08	030811878-0010	South Face - East end at corner (scaffolding level)	4/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST16-4/21/08	030811878-0011	East Face - North end at corner (scaffolding level)	4/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST17-4/21/08	030811878-0012	North Face - West end at corner (scaffolding level)	4/21/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/22/08	< 13.00	No	No	
ASBESTOS-ST1-4/22/08	030812019-0001	Southwest Area (sidewalk bridge level)	4/22/08	1	3.320	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST2-4/22/08	030812019-0002	Southeast Area (sidewalk bridge level)	4/22/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST4-4/22/08	030812019-0003	Northwest Area (street-level)	4/22/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST5-4/22/08	030812019-0004	Firehouse #10 (roof level)	4/22/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST10-4/22/08	030812019-0005	North Side Sidewalk Bridge	4/22/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST11-4/22/08	030812019-0006	90 Trinity Place (roof level)	4/22/08	1	2.760	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST12-4/22/08	030812019-0007	110 Greenwich Street (roof level)	4/22/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST13-4/22/08	030812019-0008	Marriott Hotel, 38th Floor (roof level)	4/22/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST14-4/22/08	030812019-0009	West Face - South end at corner (scaffolding level)	4/22/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST15-4/22/08	030812019-0010	South Face - East end at corner (scaffolding level)	4/22/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST16-4/22/08	030812019-0011	East Face - North end at corner (scaffolding level)	4/22/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	
ASBESTOS-ST17-4/22/08	030812019-0012	North Face - West end at corner (scaffolding level)	4/22/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/23/08	< 13.00	No	No	