

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-4/23/07	030712546-0001	Southwest Area (sidewalk bridge level)	4/23/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST2-4/23/07	030712546-0002	Southeast Area (sidewalk bridge level)	4/23/07	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST4-4/23/07	030712546-0003	Northwest Area (street-level)	4/23/07	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST5-4/23/07	030712546-0004	Firehouse #10 (roof level)	4/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST10-4/23/07	030712546-0005	North Side Sidewalk Bridge	4/23/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST11-4/23/07	030712546-0006	90 Trinity Place (roof level)	4/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST12-4/23/07	030712546-0007	110 Greenwich Street (roof level)	4/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST13-4/23/07	030712546-0008	Marriott Hotel, 38th Floor (roof level)	4/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST14-4/23/07	030712546-0009	West Face - South end at corner (scaffolding level)	4/23/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST15-4/23/07	030712546-0010	South Face - East end at corner (scaffolding level)	4/23/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST16-4/23/07	030712546-0011	East Face - North end at corner (scaffolding level)	4/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST17-4/23/07	030712546-0012	North Face - West end at corner (scaffolding level)	4/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/24/07	< 13.00	No	No	
ASBESTOS-ST1-4/24/07	030712709-0001	Southwest Area (sidewalk bridge level)	4/24/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST2-4/24/07	030712709-0002	Southeast Area (sidewalk bridge level)	4/24/07	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 0.90	No	No	
ASBESTOS-ST4-4/24/07	030712709-0003	Northwest Area (street-level)	4/24/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST5-4/24/07	030712709-0004	Firehouse #10 (roof level)	4/24/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST10-4/24/07	030712709-0005	North Side Sidewalk Bridge	4/24/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST11-4/24/07	030712709-0006	90 Trinity Place (roof level)	4/24/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST12-4/24/07	030712709-0007	110 Greenwich Street (roof level)	4/24/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST13-4/24/07	030712709-0008	Marriott Hotel, 38th Floor (roof level)	4/24/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST14-4/24/07	030712709-0009	West Face - South end at corner (scaffolding level)	4/24/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST15-4/24/07	030712709-0010	South Face - East end at corner (scaffolding level)	4/24/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST16-4/24/07	030712709-0011	East Face - North end at corner (scaffolding level)	4/24/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	
ASBESTOS-ST17-4/24/07	030712709-0012	North Face - West end at corner (scaffolding level)	4/24/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	4/25/07	< 13.00	No	No	