

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-5/16/09	030912458-0001	Southwest Area (sidewalk bridge level)	5/16/09	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST2-5/16/09	030912458-0002	Southeast Area (sidewalk bridge level)	5/16/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST4-5/16/09	030912458-0003	Northwest Area (street-level)	5/16/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST5-5/16/09	030912458-0004	Firehouse #10 (roof level)	5/16/09	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST10-5/16/09	030912458-0005	North Side Sidewalk Bridge	5/16/09	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST11-5/16/09	030912458-0006	90 Trinity Place (roof level)	5/16/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST12-5/16/09	030912458-0007	110 Greenwich Street (roof level)	5/16/09	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST13-5/16/09	030912458-0008	Marriott Hotel, 38th Floor (roof level)	5/16/09	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST14-5/16/09	030912458-0009	West Face - South end at corner (scaffolding level)	5/16/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST15-5/16/09	030912458-0010	South Face - East end at corner (scaffolding level)	5/16/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST16-5/16/09	030912458-0011	East Face - North end at corner (scaffolding level)	5/16/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST17-5/16/09	030912458-0012	North Face - West end at corner (scaffolding level)	5/16/09	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST1-5/17/09	030912459-0001	Southwest Area (sidewalk bridge level)	5/17/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST2-5/17/09	030912459-0002	Southeast Area (sidewalk bridge level)	5/17/09	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST4-5/17/09	030912459-0003	Northwest Area (street-level)	5/17/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST5-5/17/09	030912459-0004	Firehouse #10 (roof level)	5/17/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST10-5/17/09	030912459-0005	North Side Sidewalk Bridge	5/17/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST11-5/17/09	030912459-0006	90 Trinity Place (roof level)	5/17/09	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST12-5/17/09	030912459-0007	110 Greenwich Street (roof level)	5/17/09	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST13-5/17/09	030912459-0008	Marriott Hotel, 38th Floor (roof level)	5/17/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST14-5/17/09	030912459-0009	West Face - South end at corner (scaffolding level)	5/17/09	1	3.250	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST15-5/17/09	030912459-0010	South Face - East end at corner (scaffolding level)	5/17/09	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST16-5/17/09	030912459-0011	East Face - North end at corner (scaffolding level)	5/17/09	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	
ASBESTOS-ST17-5/17/09	030912459-0012	North Face - West end at corner (scaffolding level)	5/17/09	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/18/09	< 13.00	No	No	