

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-5/23/07	030716656-0001	Southwest Area (sidewalk bridge level)	5/23/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST2-5/23/07	030716656-0002	Southeast Area (sidewalk bridge level)	5/23/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST4-5/23/07	030716656-0003	Northwest Area (street-level)	5/23/07	1	3.290	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST5-5/23/07	030716656-0004	Firehouse #10 (roof level)	5/23/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST10-5/23/07	030716656-0005	North Side Sidewalk Bridge	5/23/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST100-5/23/07	030716656-0013	Station 10 Field Duplicate	5/23/07	1	3.290	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST11-5/23/07	030716656-0006	90 Trinity Place (roof level)	5/23/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST12-5/23/07	030716656-0007	110 Greenwich Street (roof level)	5/23/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST13-5/23/07	030716656-0008	Marriott Hotel, 38th Floor (roof level)	5/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST14-5/23/07	030716656-0009	West Face - South end at corner (scaffolding level)	5/23/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST15-5/23/07	030716656-0010	South Face - East end at corner (scaffolding level)	5/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST16-5/23/07	030716656-0011	East Face - North end at corner (scaffolding level)	5/23/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST17-5/23/07	030716656-0012	North Face - West end at corner (scaffolding level)	5/23/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/24/07	< 13.00	No	No		
ASBESTOS-ST1-5/24/07	030716805-0001	Southwest Area (sidewalk bridge level)	5/24/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST2-5/24/07	030716805-0002	Southeast Area (sidewalk bridge level)	5/24/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST4-5/24/07	030716805-0003	Northwest Area (street-level)	5/24/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST5-5/24/07	030716805-0004	Firehouse #10 (roof level)	5/24/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST10-5/24/07	030716805-0005	North Side Sidewalk Bridge	5/24/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST11-5/24/07	030716805-0006	90 Trinity Place (roof level)	5/24/07	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST12-5/24/07	030716805-0007	110 Greenwich Street (roof level)	5/24/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST13-5/24/07	030716805-0008	Marriott Hotel, 38th Floor (roof level)	5/24/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST14-5/24/07	030716805-0009	West Face - South end at corner (scaffolding level)	5/24/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST15-5/24/07	030716805-0010	South Face - East end at corner (scaffolding level)	5/24/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST16-5/24/07	030716805-0011	East Face - North end at corner (scaffolding level)	5/24/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		
ASBESTOS-ST17-5/24/07	030716805-0012	North Face - West end at corner (scaffolding level)	5/24/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/25/07	< 13.00	No	No		