

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
										NA	Air Quality Levels	Site Specific Trigger Levels		
										70				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-5/29/08	030816565-0001	Southwest Area (sidewalk bridge level)	5/29/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST2-5/29/08	030816565-0002	Southeast Area (sidewalk bridge level)	5/29/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST4-5/29/08	030816565-0003	Northwest Area (street-level)	5/29/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST5-5/29/08	030816565-0004	Firehouse #10 (roof level)	5/29/08	1	2.880	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST10-5/29/08	030816565-0005	North Side Sidewalk Bridge	5/29/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST11-5/29/08	030816565-0006	90 Trinity Place (roof level)	5/29/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST12-5/29/08	030816565-0007	110 Greenwich Street (roof level)	5/29/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST13-5/29/08	030816565-0008	Marriott Hotel, 38th Floor (roof level)	5/29/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST14-5/29/08	030816565-0009	West Face - South end at corner (scaffolding level)	5/29/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST15-5/29/08	030816565-0010	South Face - East end at corner (scaffolding level)	5/29/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST16-5/29/08	030816565-0011	East Face - North end at corner (scaffolding level)	5/29/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST17-5/29/08	030816565-0012	North Face - West end at corner (scaffolding level)	5/29/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/30/08	< 13.00	No	No		
ASBESTOS-ST1-5/30/08	030816711-0001	Southwest Area (sidewalk bridge level)	5/30/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST2-5/30/08	030816711-0002	Southeast Area (sidewalk bridge level)	5/30/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST4-5/30/08	030816711-0003	Northwest Area (street-level)	5/30/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST5-5/30/08	030816711-0004	Firehouse #10 (roof level)	5/30/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST10-5/30/08	030816711-0005	North Side Sidewalk Bridge	5/30/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST11-5/30/08	030816711-0006	90 Trinity Place (roof level)	5/30/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST12-5/30/08	030816711-0007	110 Greenwich Street (roof level)	5/30/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST13-5/30/08	030816711-0008	Marriott Hotel, 38th Floor (roof level)	5/30/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST14-5/30/08	030816711-0009	West Face - South end at corner (scaffolding level)	5/30/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST15-5/30/08	030816711-0010	South Face - East end at corner (scaffolding level)	5/30/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST16-5/30/08	030816711-0011	East Face - North end at corner (scaffolding level)	5/30/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST17-5/30/08	030816711-0012	North Face - West end at corner (scaffolding level)	5/30/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	5/31/08	< 13.00	No	No		
ASBESTOS-ST1-5/31/08	030816963-0001	Southwest Area (sidewalk bridge level)	5/31/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST2-5/31/08	030816963-0002	Southeast Area (sidewalk bridge level)	5/31/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST4-5/31/08	030816963-0003	Northwest Area (street-level)	5/31/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST5-5/31/08	030816963-0004	Firehouse #10 (roof level)	5/31/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST10-5/31/08	030816963-0005	North Side Sidewalk Bridge	5/31/08	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST11-5/31/08	030816963-0006	90 Trinity Place (roof level)	5/31/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST12-5/31/08	030816963-0007	110 Greenwich Street (roof level)	5/31/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST13-5/31/08	030816963-0008	Marriott Hotel, 38th Floor (roof level)	5/31/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST14-5/31/08	030816963-0009	West Face - South end at corner (scaffolding level)	5/31/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST15-5/31/08	030816963-0010	South Face - East end at corner (scaffolding level)	5/31/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST16-5/31/08	030816963-0011	East Face - North end at corner (scaffolding level)	5/31/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		
ASBESTOS-ST17-5/31/08	030816963-0012	North Face - West end at corner (scaffolding level)	5/31/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/3/08	< 13.00	No	No		