

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
ASBESTOS-ST1-6/3/08	030817200-0001	Southwest Area (sidewalk bridge level)	6/3/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST2-6/3/08	030817200-0002	Southeast Area (sidewalk bridge level)	6/3/08	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST4-6/3/08	030817200-0003	Northwest Area (street-level)	6/3/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST5-6/3/08	030817200-0004	Firehouse #10 (roof level)	6/3/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST10-6/3/08	030817200-0005	North Side Sidewalk Bridge	6/3/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST11-6/3/08	030817200-0006	90 Trinity Place (roof level)	6/3/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST12-6/3/08	030817200-0007	110 Greenwich Street (roof level)	6/3/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST13-6/3/08	030817200-0008	Marriott Hotel, 38th Floor (roof level)	6/3/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST14-6/3/08	030817200-0009	West Face - South end at corner (scaffolding level)	6/3/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST15-6/3/08	030817200-0010	South Face - East end at corner (scaffolding level)	6/3/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST16-6/3/08	030817200-0011	East Face - North end at corner (scaffolding level)	6/3/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST17-6/3/08	030817200-0012	North Face - West end at corner (scaffolding level)	6/3/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST1-6/4/08	030817259-0001	Southwest Area (sidewalk bridge level)	6/4/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 15.00	No	No	
ASBESTOS-ST2-6/4/08	030817259-0002	Southeast Area (sidewalk bridge level)	6/4/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST4-6/4/08	030817259-0003	Northwest Area (street-level)	6/4/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST5-6/4/08	030817259-0004	Firehouse #10 (roof level)	6/4/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST10-6/4/08	030817259-0005	North Side Sidewalk Bridge	6/4/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST11-6/4/08	030817259-0006	90 Trinity Place (roof level)	6/4/08	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST12-6/4/08	030817259-0007	110 Greenwich Street (roof level)	6/4/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST13-6/4/08	030817259-0008	Marriott Hotel, 38th Floor (roof level)	6/4/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST14-6/4/08	030817259-0009	West Face - South end at corner (scaffolding level)	6/4/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST15-6/4/08	030817259-0010	South Face - East end at corner (scaffolding level)	6/4/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST16-6/4/08	030817259-0011	East Face - North end at corner (scaffolding level)	6/4/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	
ASBESTOS-ST17-6/4/08	030817259-0012	North Face - West end at corner (scaffolding level)	6/4/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/5/08	< 13.00	No	No	