

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-6/8/07	030718738-0001	Southwest Area (sidewalk bridge level)	6/8/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST2-6/8/07	030718738-0002	Southeast Area (sidewalk bridge level)	6/8/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST4-6/8/07	030718738-0003	Northwest Area (street-level)	6/8/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST5-6/8/07	030718738-0004	Firehouse #10 (roof level)	6/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST10-6/8/07	030718738-0005	North Side Sidewalk Bridge	6/8/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST100-6/8/07	030718738-0013	Station 10 Field Duplicate	6/8/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST11-6/8/07	030718738-0006	90 Trinity Place (roof level)	6/8/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST12-6/8/07	030718738-0007	110 Greenwich Street (roof level)	6/8/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST13-6/8/07	030718738-0008	Marriott Hotel, 38th Floor (roof level)	6/8/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST14-6/8/07	030718738-0009	West Face - South end at corner (scaffolding level)	6/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST15-6/8/07	030718738-0010	South Face - East end at corner (scaffolding level)	6/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST16-6/8/07	030718738-0011	East Face - North end at corner (scaffolding level)	6/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST17-6/8/07	030718738-0012	North Face - West end at corner (scaffolding level)	6/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST1-6/9/07	360700730-0001	Southwest Area (sidewalk bridge level)	6/9/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 0.41	No	No	
ASBESTOS-ST2-6/9/07	030718740-0002	Southeast Area (sidewalk bridge level)	6/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST4-6/9/07	030718740-0003	Northwest Area (street-level)	6/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST5-6/9/07	030718740-0004	Firehouse #10 (roof level)	6/9/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST10-6/9/07	030718740-0005	North Side Sidewalk Bridge	6/9/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST11-6/9/07	030718740-0006	90 Trinity Place (roof level)	6/9/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST12-6/9/07	030718740-0007	110 Greenwich Street (roof level)	6/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST13-6/9/07	030718740-0008	Marriott Hotel, 38th Floor (roof level)	6/9/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST14-6/9/07	030718740-0009	West Face - South end at corner (scaffolding level)	6/9/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 15.00	No	No	
ASBESTOS-ST15-6/9/07	030718740-0010	South Face - East end at corner (scaffolding level)	6/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST16-6/9/07	030718740-0011	East Face - North end at corner (scaffolding level)	6/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	
ASBESTOS-ST17-6/9/07	030718740-0012	North Face - West end at corner (scaffolding level)	6/9/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/11/07	< 13.00	No	No	