

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels											Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels													
											NA		
											70		
ASBESTOS -ST1-6/13/07	030719224-0001	Southwest Area (sidewalk bridge level)	6/13/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST2-6/13/07	030719224-0002	Southeast Area (sidewalk bridge level)	6/13/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST4-6/13/07	030719224-0003	Northwest Area (street-level)	6/13/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST5-6/13/07	030719224-0004	Firehouse #10 (roof level)	6/13/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST10-6/13/07	030719224-0005	North Side Sidewalk Bridge	6/13/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST11-6/13/07	030719224-0006	90 Trinity Place (roof level)	6/13/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST12-6/13/07	030719224-0007	110 Greenwich Street (roof level)	6/13/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST13-6/13/07	030719224-0008	Marriott Hotel, 38th Floor (roof level)	6/13/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST14-6/13/07	030719224-0009	West Face - South end at corner (scaffolding level)	6/13/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST15-6/13/07	030719224-0010	South Face - East end at corner (scaffolding level)	6/13/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST16-6/13/07	030719224-0011	East Face - North end at corner (scaffolding level)	6/13/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS -ST17-6/13/07	030719224-0012	North Face - West end at corner (scaffolding level)	6/13/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/14/07	< 13.00	No	No	
ASBESTOS-ST1-6/14/07	030719377-0001	Southwest Area (sidewalk bridge level)	6/14/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST2-6/14/07	030719377-0002	Southeast Area (sidewalk bridge level)	6/14/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST4-6/14/07	030719377-0003	Northwest Area (street-level)	6/14/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST5-6/14/07	030719377-0004	Firehouse #10 (roof level)	6/14/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST10-6/14/07	030719377-0005	North Side Sidewalk Bridge	6/14/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST11-6/14/07	030719377-0006	90 Trinity Place (roof level)	6/14/07	1	2.910	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST12-6/14/07	030719377-0007	110 Greenwich Street (roof level)	6/14/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST13-6/14/07	030719377-0008	Marriott Hotel, 38th Floor (roof level)	6/14/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST14-6/14/07	030719377-0009	West Face - South end at corner (scaffolding level)	6/14/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST15-6/14/07	030719377-0010	South Face - East end at corner (scaffolding level)	6/14/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST16-6/14/07	030719377-0011	East Face - North end at corner (scaffolding level)	6/14/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	
ASBESTOS-ST17-6/14/07	030719377-0012	North Face - West end at corner (scaffolding level)	6/14/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/15/07	< 13.00	No	No	