

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-6/21/08	030819670-0001	Southwest Area (sidewalk bridge level)	6/21/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST2-6/21/08	030819670-0002	Southeast Area (sidewalk bridge level)	6/21/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST4-6/21/08	030819670-0003	Northwest Area (street-level)	6/21/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST5-6/21/08	030819670-0004	Firehouse #10 (roof level)	6/21/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST10-6/21/08	030819670-0005	North Side Sidewalk Bridge	6/21/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST11-6/21/08	030819670-0006	90 Trinity Place (roof level)	6/21/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST12-6/21/08	030819670-0007	110 Greenwich Street (roof level)	6/21/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST13-6/21/08	030819670-0008	Marriott Hotel, 38th Floor (roof level)	6/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST14-6/21/08	030819670-0009	West Face - South end at corner (scaffolding level)	6/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST15-6/21/08	030819670-0010	South Face - East end at corner (scaffolding level)	6/21/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST16-6/21/08	030819670-0011	East Face - North end at corner (scaffolding level)	6/21/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST17-6/21/08	030819670-0012	North Face - West end at corner (scaffolding level)	6/21/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST1-6/22/08	030819674-0001	Southwest Area (sidewalk bridge level)	6/22/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST2-6/22/08	030819674-0002	Southeast Area (sidewalk bridge level)	6/22/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST4-6/22/08	030819674-0003	Northwest Area (street-level)	6/22/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST5-6/22/08	030819674-0004	Firehouse #10 (roof level)	6/22/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST10-6/22/08	030819674-0005	North Side Sidewalk Bridge	6/22/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST11-6/22/08	030819674-0006	90 Trinity Place (roof level)	6/22/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST12-6/22/08	030819674-0007	110 Greenwich Street (roof level)	6/22/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST13-6/22/08	030819674-0008	Marriott Hotel, 38th Floor (roof level)	6/22/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST14-6/22/08	030819674-0009	West Face - South end at corner (scaffolding level)	6/22/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST15-6/22/08	030819674-0010	South Face - East end at corner (scaffolding level)	6/22/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST16-6/22/08	030819674-0011	East Face - North end at corner (scaffolding level)	6/22/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	
ASBESTOS-ST17-6/22/08	030819674-0012	North Face - West end at corner (scaffolding level)	6/22/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/23/08	< 13.00	No	No	