

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels											NA		
EPA Site Specific Trigger Levels											70		
ASBESTOS-ST1-6/25/07	030720821-0001	Southwest Area (sidewalk bridge level)	6/25/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 13.00	No	No	
ASBESTOS-ST2-6/25/07	030720821-0002	Southeast Area (sidewalk bridge level)	6/25/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 13.00	No	No	
ASBESTOS-ST4-6/25/07	030720821-0003	Northwest Area (street-level)	6/25/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 15.00	No	No	
ASBESTOS-ST5-6/25/07	030720821-0004	Firehouse #10 (roof level)	6/25/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 15.00	No	No	
ASBESTOS-ST10-6/25/07	030720821-0005	North Side Sidewalk Bridge	6/25/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 15.00	No	No	
ASBESTOS-ST11-6/25/07	030720821-0006	90 Trinity Place (roof level)	6/25/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 13.00	No	No	
ASBESTOS-ST12-6/25/07	030720821-0007	110 Greenwich Street (roof level)	6/25/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 13.00	No	No	
ASBESTOS-ST13-6/25/07	030720821-0008	Marriott Hotel, 38th Floor (roof level)	6/25/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 15.00	No	No	
ASBESTOS-ST14-6/25/07	030720821-0009	West Face - South end at corner (scaffolding level)	6/25/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 15.00	No	No	
ASBESTOS-ST15-6/25/07	030720821-0010	South Face - East end at corner (scaffolding level)	6/25/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 13.00	No	No	
ASBESTOS-ST16-6/25/07	030720821-0011	East Face - North end at corner (scaffolding level)	6/25/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 13.00	No	No	
ASBESTOS-ST17-6/25/07	030720821-0012	North Face - West end at corner (scaffolding level)	6/25/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/26/07	< 13.00	No	No	
ASBESTOS-ST1-6/26/07	030720983-0001	Southwest Area (sidewalk bridge level)	6/26/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	
ASBESTOS-ST2-6/26/07	030720983-0002	Southeast Area (sidewalk bridge level)	6/26/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 15.00	No	No	
ASBESTOS-ST4-6/26/07	030720983-0003	Northwest Area (street-level)	6/26/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	
ASBESTOS-ST5-6/26/07	030720983-0004	Firehouse #10 (roof level)	6/26/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 15.00	No	No	
ASBESTOS-ST10-6/26/07	030720983-0005	North Side Sidewalk Bridge	6/26/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	
ASBESTOS-ST100-6/26/07	030720983-0013	Station 10 Field Duplicate	6/26/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	
ASBESTOS-ST11-6/26/07	030720983-0006	90 Trinity Place (roof level)	6/26/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	
ASBESTOS-ST12-6/26/07	030720983-0007	110 Greenwich Street (roof level)	6/26/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	
ASBESTOS-ST13-6/26/07	030720983-0008	Marriott Hotel, 38th Floor (roof level)	6/26/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	
ASBESTOS-ST14-6/26/07	030720983-0009	West Face - South end at corner (scaffolding level)	6/26/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 15.00	No	No	
ASBESTOS-ST15-6/26/07	030720983-0010	South Face - East end at corner (scaffolding level)	6/26/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	
ASBESTOS-ST16-6/26/07	030720983-0011	East Face - North end at corner (scaffolding level)	6/26/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 15.00	No	No	
ASBESTOS-ST17-6/26/07	030720983-0012	North Face - West end at corner (scaffolding level)	6/26/07	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	6/27/07	< 13.00	No	No	