

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
<b>Target Air Quality Levels</b>										<b>NA</b>			
<b>EPA Site Specific Trigger Levels</b>										<b>70</b>			
ASBESTOS-ST2-7/9/07	030722626-0001	Southeast Area (sidewalk bridge level)	7/9/07	1	3.018	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST4-7/9/07	030722626-0002	Northwest Area (street-level)	7/9/07	1	2.770	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST5-7/9/07	030722626-0003	Firehouse #10 (roof level)	7/9/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST10-7/9/07	030722626-0004	North Side Sidewalk Bridge	7/9/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST11-7/9/07	030722626-0005	90 Trinity Place (roof level)	7/9/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST12-7/9/07	030722626-0006	110 Greenwich Street (roof level)	7/9/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST13-7/9/07	030722626-0007	Marriott Hotel, 38th Floor (roof level)	7/9/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST14-7/9/07	030722626-0008	West Face - South end at corner (scaffolding level)	7/9/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST15-7/9/07	030722626-0009	South Face - East end at corner (scaffolding level)	7/9/07	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST16-7/9/07	030722626-0010	East Face - North end at corner (scaffolding level)	7/9/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST17-7/9/07	030722626-0011	North Face - West end at corner (scaffolding level)	7/9/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/10/07	< 13.00	No	No	
ASBESTOS-ST1-7/10/07	030722792-0001	Southwest Area (sidewalk bridge level)	7/10/07	1	2.520	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 11.00	No	No	
ASBESTOS-ST2-7/10/07	030722792-0002	Southeast Area (sidewalk bridge level)	7/10/07	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST4-7/10/07	030722792-0003	Northwest Area (street-level)	7/10/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 15.00	No	No	
ASBESTOS-ST5-7/10/07	030722792-0004	Firehouse #10 (roof level)	7/10/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST10-7/10/07	030722792-0005	North Side Sidewalk Bridge	7/10/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST11-7/10/07	030722792-0006	90 Trinity Place (roof level)	7/10/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST12-7/10/07	030722792-0007	110 Greenwich Street (roof level)	7/10/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST13-7/10/07	030722792-0008	Marriott Hotel, 38th Floor (roof level)	7/10/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST14-7/10/07	030722792-0009	West Face - South end at corner (scaffolding level)	7/10/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST15-7/10/07	030722792-0010	South Face - East end at corner (scaffolding level)	7/10/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST16-7/10/07	030722792-0011	East Face - North end at corner (scaffolding level)	7/10/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	
ASBESTOS-ST17-7/10/07	030722792-0012	North Face - West end at corner (scaffolding level)	7/10/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/11/07	< 13.00	No	No	

Note:

- Asbestos sample at Station 1 (Southwest Area [sidewalk bridge level]) on July 9, 2007 was not available for analysis on account of timer malfunction