

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-7/11/07	030722946-0001	Southwest Area (sidewalk bridge level)	7/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST4-7/11/07	030722946-0002	Northwest Area (street-level)	7/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST5-7/11/07	030722946-0003	Firehouse #10 (roof level)	7/11/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST10-7/11/07	030722946-0004	North Side Sidewalk Bridge	7/11/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST11-7/11/07	030722946-0005	90 Trinity Place (roof level)	7/11/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST12-7/11/07	030722946-0006	110 Greenwich Street (roof level)	7/11/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST13-7/11/07	030722946-0007	Marriott Hotel, 38th Floor (roof level)	7/11/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST14-7/11/07	030722946-0008	West Face - South end at corner (scaffolding level)	7/11/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST15-7/11/07	030722946-0009	South Face - East end at corner (scaffolding level)	7/11/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST16-7/11/07	030722946-0010	East Face - North end at corner (scaffolding level)	7/11/07	1	2.800	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST17-7/11/07	030722946-0011	North Face - West end at corner (scaffolding level)	7/11/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/12/07	< 13.00	No	No	
ASBESTOS-ST1-7/12/07	030723088-0001	Southwest Area (sidewalk bridge level)	7/12/07	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST2-7/12/07	030723088-0002	Southeast Area (sidewalk bridge level)	7/12/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST4-7/12/07	030723088-0003	Northwest Area (street-level)	7/12/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST5-7/12/07	030723088-0004	Firehouse #10 (roof level)	7/12/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST10-7/12/07	030723088-0005	North Side Sidewalk Bridge	7/12/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST11-7/12/07	030723088-0006	90 Trinity Place (roof level)	7/12/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST12-7/12/07	030723088-0007	110 Greenwich Street (roof level)	7/12/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST13-7/12/07	030723088-0008	Marriott Hotel, 38th Floor (roof level)	7/12/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST14-7/12/07	030723088-0009	West Face - South end at corner (scaffolding level)	7/12/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST15-7/12/07	030723088-0010	South Face - East end at corner (scaffolding level)	7/12/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST16-7/12/07	030723088-0011	East Face - North end at corner (scaffolding level)	7/12/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	
ASBESTOS-ST17-7/12/07	030723088-0012	North Face - West end at corner (scaffolding level)	7/12/07	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/13/07	< 13.00	No	No	

Note:

1. Asbestos sample at Station 2 (Southeast Area [sidewalk bridge level]) on July 11, 2007 was not available for analysis on account of timer malfunction.