

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA				
										70				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-7/24/08	030824844-0001	Southwest Area (sidewalk bridge level)	7/24/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST2-7/24/08	030824844-0002	Southeast Area (sidewalk bridge level)	7/24/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST4-7/24/08	030824844-0003	Northwest Area (street-level)	7/24/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST5-7/24/08	030824844-0004	Firehouse #10 (roof level)	7/24/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST10-7/24/08	030824844-0005	North Side Sidewalk Bridge	7/24/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST11-7/24/08	030824844-0006	90 Trinity Place (roof level)	7/24/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST12-7/24/08	030824844-0007	110 Greenwich Street (roof level)	7/24/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST13-7/24/08	030824844-0008	Marriott Hotel, 38th Floor (roof level)	7/24/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST14-7/24/08	030824844-0009	West Face - South end at corner (scaffolding level)	7/24/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST15-7/24/08	030824844-0010	South Face - East end at corner (scaffolding level)	7/24/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST16-7/24/08	030824844-0011	East Face - North end at corner (scaffolding level)	7/24/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST17-7/24/08	030824844-0012	North Face - West end at corner (scaffolding level)	7/24/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/25/08	< 13.00		No	No	
ASBESTOS-ST1-7/25/08	030825056-0001	Southwest Area (sidewalk bridge level)	7/25/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST2-7/25/08	030825056-0002	Southeast Area (sidewalk bridge level)	7/25/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST4-7/25/08	030825056-0003	Northwest Area (street-level)	7/25/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST5-7/25/08	030825056-0004	Firehouse #10 (roof level)	7/25/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST10-7/25/08	030825056-0005	North Side Sidewalk Bridge	7/25/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST100-7/25/08	030825056-0013	Station 10 Field Duplicate	7/25/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST11-7/25/08	030825056-0006	90 Trinity Place (roof level)	7/25/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST12-7/25/08	030825056-0007	110 Greenwich Street (roof level)	7/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST13-7/25/08	030825056-0008	Marriott Hotel, 38th Floor (roof level)	7/25/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST14-7/25/08	030825056-0009	West Face - South end at corner (scaffolding level)	7/25/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST15-7/25/08	030825056-0010	South Face - East end at corner (scaffolding level)	7/25/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST16-7/25/08	030825056-0011	East Face - North end at corner (scaffolding level)	7/25/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST17-7/25/08	030825056-0012	North Face - West end at corner (scaffolding level)	7/25/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/26/08	< 13.00		No	No	
ASBESTOS-ST1-7/26/08	030825250-0001	Southwest Area (sidewalk bridge level)	7/26/08	1	3.240	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST2-7/26/08	030825250-0002	Southeast Area (sidewalk bridge level)	7/26/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST4-7/26/08	030825250-0003	Northwest Area (street-level)	7/26/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST5-7/26/08	030825250-0004	Firehouse #10 (roof level)	7/26/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST10-7/26/08	030825250-0005	North Side Sidewalk Bridge	7/26/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST11-7/26/08	030825250-0006	90 Trinity Place (roof level)	7/26/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST12-7/26/08	030825250-0007	110 Greenwich Street (roof level)	7/26/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST13-7/26/08	030825250-0008	Marriott Hotel, 38th Floor (roof level)	7/26/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST14-7/26/08	030825250-0009	West Face - South end at corner (scaffolding level)	7/26/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST15-7/26/08	030825250-0010	South Face - East end at corner (scaffolding level)	7/26/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST16-7/26/08	030825250-0011	East Face - North end at corner (scaffolding level)	7/26/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST17-7/26/08	030825250-0012	North Face - West end at corner (scaffolding level)	7/26/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/08	< 13.00		No	No	
ASBESTOS-ST1-7/27/08	030825253-0001	Southwest Area (sidewalk bridge level)	7/27/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST2-7/27/08	030825253-0002	Southeast Area (sidewalk bridge level)	7/27/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST4-7/27/08	030825253-0003	Northwest Area (street-level)	7/27/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST5-7/27/08	030825253-0004	Firehouse #10 (roof level)	7/27/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST10-7/27/08	030825253-0005	North Side Sidewalk Bridge	7/27/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST11-7/27/08	030825253-0006	90 Trinity Place (roof level)	7/27/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST12-7/27/08	030825253-0007	110 Greenwich Street (roof level)	7/27/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST13-7/27/08	030825253-0008	Marriott Hotel, 38th Floor (roof level)	7/27/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST14-7/27/08	030825253-0009	West Face - South end at corner (scaffolding level)	7/27/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST15-7/27/08	030825253-0010	South Face - East end at corner (scaffolding level)	7/27/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST16-7/27/08	030825253-0011	East Face - North end at corner (scaffolding level)	7/27/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	
ASBESTOS-ST17-7/27/08	030825253-0012	North Face - West end at corner (scaffolding level)	7/27/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/08	< 13.00		No	No	