

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-7/26/06	030623698-0001	Southwest Area (sidewalk bridge level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST2-7/26/06	030623698-0002	Southeast Area (sidewalk bridge level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST4-7/26/06	030623698-0003	Northwest Area (street-level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST5-7/26/06	030623698-0004	Firehouse #10 (roof level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST6-7/26/06	030623702-0001	Southwest Area (roof level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST7-7/26/06	030623702-0002	Southeast Area (roof level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	13.00	No	No	
ASBESTOS-ST8-7/26/06	030623702-0003	Northeast Area (roof level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST9-7/26/06	030623702-0004	Northwest Area (roof level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST10-7/26/06	030623698-0005	North Side Sidewalk Bridge	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST11-7/26/06	030623698-0006	90 Trinity Place (roof level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST12-7/26/06	030623698-0007	110 Greenwich Street (roof level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST13-7/26/06	030623698-0008	Marriott Hotel, 38th Floor (roof level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST14-7/26/06	030623698-0009	West Face - South end at corner (scaffolding level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST15-7/26/06	030623698-0010	South Face - East end at corner (scaffolding level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST16-7/26/06	030623698-0011	East Face - North end at corner (scaffolding level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	
ASBESTOS-ST17-7/26/06	030623698-0012	North Face - West end at corner (scaffolding level)	7/26/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/27/06	< 13.00	No	No	