

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels										70	Levels	Trigger Levels	
ASBESTOS-ST1-7/27/07	030725327-0001	Southwest Area (sidewalk bridge level)	7/27/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST2-7/27/07	030725327-0002	Southeast Area (sidewalk bridge level)	7/27/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST4-7/27/07	030725327-0003	Northwest Area (street-level)	7/27/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST5-7/27/07	030725327-0004	Firehouse #10 (roof level)	7/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST10-7/27/07	030725327-0005	North Side Sidewalk Bridge	7/27/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST11-7/27/07	030725327-0006	90 Trinity Place (roof level)	7/27/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST12-7/27/07	030725327-0007	110 Greenwich Street (roof level)	7/27/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST13-7/27/07	030725327-0008	Marriott Hotel, 38th Floor (roof level)	7/27/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST14-7/27/07	030725327-0009	West Face - South end at corner (scaffolding level)	7/27/07	1	2.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST15-7/27/07	030725327-0010	South Face - East end at corner (scaffolding level)	7/27/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST16-7/27/07	030725327-0011	East Face - North end at corner (scaffolding level)	7/27/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST17-7/27/07	030725327-0012	North Face - West end at corner (scaffolding level)	7/27/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/28/07	< 13.00	No	No	
ASBESTOS-ST1-7/28/2007	030725545-0001	Southwest Area (sidewalk bridge level)	7/28/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST2-7/28/2007	030725545-0002	Southeast Area (sidewalk bridge level)	7/28/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST4-7/28/2007	030725545-0003	Northwest Area (street-level)	7/28/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST5-7/28/2007	030725545-0004	Firehouse #10 (roof level)	7/28/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST10-7/28/2007	030725545-0005	North Side Sidewalk Bridge	7/28/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 15.00	No	No	
ASBESTOS-ST11-7/28/2007	030725545-0006	90 Trinity Place (roof level)	7/28/07	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST12-7/28/2007	030725545-0007	110 Greenwich Street (roof level)	7/28/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST13-7/28/2007	030725545-0008	Marriott Hotel, 38th Floor (roof level)	7/28/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST14-7/28/2007	030725545-0009	West Face - South end at corner (scaffolding level)	7/28/07	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 15.00	No	No	
ASBESTOS-ST15-7/28/2007	030725545-0010	South Face - East end at corner (scaffolding level)	7/28/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST16-7/28/2007	030725545-0011	East Face - North end at corner (scaffolding level)	7/28/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	
ASBESTOS-ST17-7/28/2007	030725545-0012	North Face - West end at corner (scaffolding level)	7/28/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/07	< 13.00	No	No	