

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-7/28/08	030825449-0001	Southwest Area (sidewalk bridge level)	7/28/08	1	3.440	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 15.00	No	No	Note 1
ASBESTOS-ST2-7/28/08	030825449-0002	Southeast Area (sidewalk bridge level)	7/28/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 15.00	No	No	
ASBESTOS-ST4-7/28/08	030825449-0003	Northwest Area (street-level)	7/28/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 15.00	No	No	
ASBESTOS-ST5-7/28/08	030825449-0004	Firehouse #10 (roof level)	7/28/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 15.00	No	No	
ASBESTOS-ST10-7/28/08	030825449-0005	North Side Sidewalk Bridge	7/28/08	1	3.240	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 15.00	No	No	
ASBESTOS-ST11-7/28/08	030825449-0006	90 Trinity Place (roof level)	7/28/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 13.00	No	No	
ASBESTOS-ST12-7/28/08	030825449-0007	110 Greenwich Street (roof level)	7/28/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 13.00	No	No	
ASBESTOS-ST13-7/28/08	030825449-0008	Marriott Hotel, 38th Floor (roof level)	7/28/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 13.00	No	No	
ASBESTOS-ST14-7/28/08	030825449-0009	West Face - South end at corner (scaffolding level)	7/28/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 13.00	No	No	
ASBESTOS-ST15-7/28/08	030825449-0010	South Face - East end at corner (scaffolding level)	7/28/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 13.00	No	No	
ASBESTOS-ST16-7/28/08	030825449-0011	East Face - North end at corner (scaffolding level)	7/28/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 13.00	No	No	
ASBESTOS-ST17-7/28/08	030825449-0012	North Face - West end at corner (scaffolding level)	7/28/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/29/08	< 13.00	No	No	
ASBESTOS-ST1-7/29/08	030825648-0001	Southwest Area (sidewalk bridge level)	7/29/08	1	3.300	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST2-7/29/08	030825648-0002	Southeast Area (sidewalk bridge level)	7/29/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST4-7/29/08	030825648-0003	Northwest Area (street-level)	7/29/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST5-7/29/08	030825648-0004	Firehouse #10 (roof level)	7/29/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST10-7/29/08	030825648-0005	North Side Sidewalk Bridge	7/29/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST11-7/29/08	030825648-0006	90 Trinity Place (roof level)	7/29/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST12-7/29/08	030825648-0007	110 Greenwich Street (roof level)	7/29/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST13-7/29/08	030825648-0008	Marriott Hotel, 38th Floor (roof level)	7/29/08	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST14-7/29/08	030825648-0009	West Face - South end at corner (scaffolding level)	7/29/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST15-7/29/08	030825648-0010	South Face - East end at corner (scaffolding level)	7/29/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST16-7/29/08	030825648-0011	East Face - North end at corner (scaffolding level)	7/29/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
ASBESTOS-ST17-7/29/08	030825648-0012	North Face - West end at corner (scaffolding level)	7/29/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	7/30/08	< 13.00	No	No	
Note:													

1. Due to flow rate RPD exceedance (24.2%) for asbestos at Station 1 (Southwest Area Sidewalk Bridge Level) on July 28, 2008, the sample volume and subsequent sample result are estimated.