

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-8/9/08	030827428-0001	Southwest Area (sidewalk bridge level)	8/9/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 15.00	No	No	
ASBESTOS-ST2-8/9/08	030827428-0002	Southeast Area (sidewalk bridge level)	8/9/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 15.00	No	No	
ASBESTOS-ST4-8/9/08	030827428-0003	Northwest Area (street-level)	8/9/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST5-8/9/08	030827428-0004	Firehouse #10 (roof level)	8/9/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST10-8/9/08	030827428-0005	North Side Sidewalk Bridge	8/9/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST11-8/9/08	030827428-0006	90 Trinity Place (roof level)	8/9/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST12-8/9/08	030827428-0007	110 Greenwich Street (roof level)	8/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST13-8/9/08	030827428-0008	Marriott Hotel, 38th Floor (roof level)	8/9/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST14-8/9/08	030827428-0009	West Face - South end at corner (scaffolding level)	8/9/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST15-8/9/08	030827428-0010	South Face - East end at corner (scaffolding level)	8/9/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST16-8/9/08	030827428-0011	East Face - North end at corner (scaffolding level)	8/9/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST17-8/9/08	030827428-0012	North Face - West end at corner (scaffolding level)	8/9/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST1-8/10/08	030827430-0001	Southwest Area (sidewalk bridge level)	8/10/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST2-8/10/08	030827430-0002	Southeast Area (sidewalk bridge level)	8/10/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST4-8/10/08	030827430-0003	Northwest Area (street-level)	8/10/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST5-8/10/08	030827430-0004	Firehouse #10 (roof level)	8/10/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST10-8/10/08	030827430-0005	North Side Sidewalk Bridge	8/10/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST11-8/10/08	030827430-0006	90 Trinity Place (roof level)	8/10/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST12-8/10/08	030827430-0007	110 Greenwich Street (roof level)	8/10/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST13-8/10/08	030827430-0008	Marriott Hotel, 38th Floor (roof level)	8/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST14-8/10/08	030827430-0009	West Face - South end at corner (scaffolding level)	8/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST15-8/10/08	030827430-0010	South Face - East end at corner (scaffolding level)	8/10/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST16-8/10/08	030827430-0011	East Face - North end at corner (scaffolding level)	8/10/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	
ASBESTOS-ST17-8/10/08	030827430-0012	North Face - West end at corner (scaffolding level)	8/10/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/11/08	< 13.00	No	No	