

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-8/13/08	030827974-0001	Southwest Area (sidewalk bridge level)	8/13/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 13.00	No	No	
ASBESTOS-ST2-8/13/08	030827974-0002	Southeast Area (sidewalk bridge level)	8/13/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 15.00	No	No	
ASBESTOS-ST4-8/13/08	030827974-0003	Northwest Area (street-level)	8/13/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 15.00	No	No	
ASBESTOS-ST5-8/13/08	030827974-0004	Firehouse #10 (roof level)	8/13/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 15.00	No	No	
ASBESTOS-ST10-8/13/08	030827974-0005	North Side Sidewalk Bridge	8/13/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 15.00	No	No	
ASBESTOS-ST11-8/13/08	030827974-0006	90 Trinity Place (roof level)	8/13/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 15.00	No	No	
ASBESTOS-ST12-8/13/08	030827974-0007	110 Greenwich Street (roof level)	8/13/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 13.00	No	No	
ASBESTOS-ST13-8/13/08	030827974-0008	Marriott Hotel, 38th Floor (roof level)	8/13/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 13.00	No	No	
ASBESTOS-ST14-8/13/08	030827974-0009	West Face - South end at corner (scaffolding level)	8/13/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 13.00	No	No	
ASBESTOS-ST15-8/13/08	030827974-0010	South Face - East end at corner (scaffolding level)	8/13/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 13.00	No	No	
ASBESTOS-ST16-8/13/08	030827974-0011	East Face - North end at corner (scaffolding level)	8/13/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 13.00	No	No	
ASBESTOS-ST17-8/13/08	030827974-0012	North Face - West end at corner (scaffolding level)	8/13/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/14/08	< 15.00	No	No	
ASBESTOS-ST1-8/14/08	030828108-0001	Southwest Area (sidewalk bridge level)	8/14/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 15.00	No	No	
ASBESTOS-ST2-8/14/08	030828108-0002	Southeast Area (sidewalk bridge level)	8/14/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 15.00	No	No	
ASBESTOS-ST4-8/14/08	030828108-0003	Northwest Area (street-level)	8/14/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 15.00	No	No	
ASBESTOS-ST5-8/14/08	030828108-0004	Firehouse #10 (roof level)	8/14/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 15.00	No	No	
ASBESTOS-ST10-8/14/08	030828108-0005	North Side Sidewalk Bridge	8/14/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 13.00	No	No	
ASBESTOS-ST11-8/14/08	030828108-0006	90 Trinity Place (roof level)	8/14/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 13.00	No	No	
ASBESTOS-ST12-8/14/08	030828108-0007	110 Greenwich Street (roof level)	8/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 13.00	No	No	
ASBESTOS-ST13-8/14/08	030828108-0008	Marriott Hotel, 38th Floor (roof level)	8/14/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 13.00	No	No	
ASBESTOS-ST14-8/14/08	030828108-0009	West Face - South end at corner (scaffolding level)	8/14/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 13.00	No	No	
ASBESTOS-ST15-8/14/08	030828108-0010	South Face - East end at corner (scaffolding level)	8/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 13.00	No	No	
ASBESTOS-ST16-8/14/08	030828108-0011	East Face - North end at corner (scaffolding level)	8/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 13.00	No	No	
ASBESTOS-ST17-8/14/08	030828108-0012	North Face - West end at corner (scaffolding level)	8/14/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/15/08	< 13.00	No	No	