

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-8/15/07	030727920-0001	Southwest Area (sidewalk bridge level)	8/15/07	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST2-8/15/07	030727920-0002	Southeast Area (sidewalk bridge level)	8/15/07	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST4-8/15/07	030727920-0003	Northwest Area (street-level)	8/15/07	1	3.340	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST5-8/15/07	030727920-0004	Firehouse #10 (roof level)	8/15/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST10-8/15/07	030727920-0005	North Side Sidewalk Bridge	8/15/07	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST11-8/15/07	030727920-0006	90 Trinity Place (roof level)	8/15/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST12-8/15/07	030727920-0007	110 Greenwich Street (roof level)	8/15/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST13-8/15/07	030727920-0008	Marriott Hotel, 38th Floor (roof level)	8/15/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST14-8/15/07	030727920-0009	West Face - South end at corner (scaffolding level)	8/15/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST15-8/15/07	030727920-0010	South Face - East end at corner (scaffolding level)	8/15/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST16-8/15/07	030727920-0011	East Face - North end at corner (scaffolding level)	8/15/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ASBESTOS-ST17-8/15/07	030727920-0012	North Face - West end at corner (scaffolding level)	8/15/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/16/07	< 13.00	No	No		
ABSESTOS-ST1-8/16/07	030728103-0001	Southwest Area (sidewalk bridge level)	8/16/07	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST2-8/16/07	030728103-0002	Southeast Area (sidewalk bridge level)	8/16/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST4-8/16/07	030728103-0003	Northwest Area (street-level)	8/16/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST5-8/16/07	030728103-0004	Firehouse #10 (roof level)	8/16/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST10-8/16/07	030728103-0005	North Side Sidewalk Bridge	8/16/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST100-8/16/07	030728103-0013	Station 10 Field Duplicate	8/16/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST11-8/16/07	030728103-0006	90 Trinity Place (roof level)	8/16/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST12-8/16/07	030728103-0007	110 Greenwich Street (roof level)	8/16/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST13-8/16/07	030728103-0008	Marriott Hotel, 38th Floor (roof level)	8/16/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST14-8/16/07	030728103-0009	West Face - South end at corner (scaffolding level)	8/16/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST15-8/16/07	030728103-0010	South Face - East end at corner (scaffolding level)	8/16/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST16-8/16/07	030728103-0011	East Face - North end at corner (scaffolding level)	8/16/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		
ABSESTOS-ST17-8/16/07	030728103-0012	North Face - West end at corner (scaffolding level)	8/16/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	8/17/07	< 13.00	No	No		