

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-9/3/07	030730213-0001	Southwest Area (sidewalk bridge level)	9/3/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 15.00	No	No	
ASBESTOS-ST2-9/3/07	030730213-0002	Southeast Area (sidewalk bridge level)	9/3/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 13.00	No	No	
ASBESTOS-ST4-9/3/07	030730213-0003	Northwest Area (street-level)	9/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 13.00	No	No	
ASBESTOS-ST5-9/3/07	030730213-0004	Firehouse #10 (roof level)	9/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 13.00	No	No	
ASBESTOS-ST10-9-3/07	030730213-0005	North Side Sidewalk Bridge	9/3/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 13.00	No	No	
ASBESTOS-ST11-9/3/07	030730213-0006	90 Trinity Place (roof level)	9/3/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 15.00	No	No	
ASBESTOS-ST12-9/3/07	030730213-0007	110 Greenwich Street (roof level)	9/3/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 15.00	No	No	
ASBESTOS-ST13-9/3/07	030730213-0008	Marriott Hotel, 38th Floor (roof level)	9/3/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 15.00	No	No	
ASBESTOS-ST14-9/3/07	030730213-0009	West Face - South end at corner (scaffolding level)	9/3/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 15.00	No	No	
ASBESTOS-ST15-9/3/07	030730213-0010	South Face - East end at corner (scaffolding level)	9/3/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 13.00	No	No	
ASBESTOS-ST16-9/3/07	030730213-0011	East Face - North end at corner (scaffolding level)	9/3/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 15.00	No	No	
ASBESTOS-ST17-9/3/07	030730213-0012	North Face - West end at corner (scaffolding level)	9/3/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/4/07	< 15.00	No	No	
ASBESTOS-ST1-9/4/07	030730334-0001	Southwest Area (sidewalk bridge level)	9/4/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	26.00	No	No	
ASBESTOS-ST2-9/4/07	030730334-0002	Southeast Area (sidewalk bridge level)	9/4/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST4-9/4/07	030730334-0003	Northwest Area (street-level)	9/4/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST5-9/4/07	030730334-0004	Firehouse #10 (roof level)	9/4/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST10-9/4/07	030730334-0005	North Side Sidewalk Bridge	9/4/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST100-9/4/07	030730334-0013	Station 10 Field Duplicate	9/4/07	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 15.00	No	No	
ASBESTOS-ST11-9/4/07	030730334-0006	90 Trinity Place (roof level)	9/4/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST12-9/4/07	030730334-0007	110 Greenwich Street (roof level)	9/4/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST13-9/4/07	030730334-0008	Marriott Hotel, 38th Floor (roof level)	9/4/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST14-9/4/07	030730334-0009	West Face - South end at corner (scaffolding level)	9/4/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 15.00	No	No	
ASBESTOS-ST15-9/4/07	030730334-0010	South Face - East end at corner (scaffolding level)	9/4/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST16-9/4/07	030730334-0011	East Face - North end at corner (scaffolding level)	9/4/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	
ASBESTOS-ST17-9/4/07	030730334-0012	North Face - West end at corner (scaffolding level)	9/4/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/5/07	< 13.00	No	No	