

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA			
										70			
ASBESTOS-ST1-9/27/06	030631750-0001	Southwest Area (sidewalk bridge level)	9/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST2-9/27/06	030631750-0002	Southeast Area (sidewalk bridge level)	9/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST4-9/27/06	030631750-0003	Northwest Area (street-level)	9/27/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST5-9/27/06	030631750-0004	Firehouse #10 (roof level)	9/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST10-9/27/06	030631750-0005	North Side Sidewalk Bridge	9/27/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST100-9/27/06	030631750-0013	Station 10 Field Duplicate	9/27/06	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST11-9/27/06	030631750-0006	90 Trinity Place (roof level)	9/27/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST12-9/27/06	030631750-0007	110 Greenwich Street (roof level)	9/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST13-9/27/06	030631750-0008	Marriott Hotel, 38th Floor (roof level)	9/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST14-9/27/06	030631750-0009	West Face - South end at corner (scaffolding level)	9/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST15-9/27/06	030631750-0010	South Face - East end at corner (scaffolding level)	9/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST16-9/27/06	030631750-0011	East Face - North end at corner (scaffolding level)	9/27/06	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST17-9/27/06	030631750-0012	North Face - West end at corner (scaffolding level)	9/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/28/06	< 13.00	No	No	
ASBESTOS-ST1-9/28/06	030631877-0001	Southwest Area (sidewalk bridge level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST2-9/28/06	030631877-0002	Southeast Area (sidewalk bridge level)	9/28/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST4-9/28/06	030631877-0003	Northwest Area (street-level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST5-9/28/06	030631877-0004	Firehouse #10 (roof level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST10-9/28/06	030631877-0005	North Side Sidewalk Bridge	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST11-9/28/06	030631877-0006	90 Trinity Place (roof level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST12-9/28/06	030631877-0007	110 Greenwich Street (roof level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST13-9/28/06	030631877-0008	Marriott Hotel, 38th Floor (roof level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST14-9/28/06	030631877-0009	West Face - South end at corner (scaffolding level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST15-9/28/06	030631877-0010	South Face - East end at corner (scaffolding level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST16-9/28/06	030631877-0011	East Face - North end at corner (scaffolding level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	
ASBESTOS-ST17-9/28/06	030631877-0012	North Face - West end at corner (scaffolding level)	9/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/29/06	< 13.00	No	No	