

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-10/1/07	030732754-0001	Southwest Area (sidewalk bridge level)	10/1/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 15.00	No	No	
ASBESTOS-ST2-10/1/07	030732754-0002	Southeast Area (sidewalk bridge level)	10/1/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 13.00	No	No	
ASBESTOS-ST4-10/1/07	030732754-0003	Northwest Area (street-level)	10/1/07	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 15.00	No	No	
ASBESTOS-ST5-10/1/07	030732754-0004	Firehouse #10 (roof level)	10/1/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 13.00	No	No	
ASBESTOS-ST10-10/1/07	030732754-0005	North Side Sidewalk Bridge	10/1/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 13.00	No	No	
ASBESTOS-ST11-10/1/07	030732754-0006	90 Trinity Place (roof level)	10/1/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 13.00	No	No	
ASBESTOS-ST12-10/1/07	030732754-0007	110 Greenwich Street (roof level)	10/1/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 15.00	No	No	
ASBESTOS-ST13-10/1/07	030732754-0008	Marriott Hotel, 38th Floor (roof level)	10/1/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 13.00	No	No	
ASBESTOS-ST14-10/1/07	030732754-0009	West Face - South end at corner (scaffolding level)	10/1/07	1	2.880	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 13.00	No	No	
ASBESTOS-ST15-10/1/07	030732754-0010	South Face - East end at corner (scaffolding level)	10/1/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 13.00	No	No	
ASBESTOS-ST16-10/1/07	030732754-0011	East Face - North end at corner (scaffolding level)	10/1/07	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 13.00	No	No	
ASBESTOS-ST17-10/1/07	030732754-0012	North Face - West end at corner (scaffolding level)	10/1/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/2/07	< 15.00	No	No	
ASBESTOS-ST1-10/2/07	030732863-0001	Southwest Area (sidewalk bridge level)	10/2/07	1	4.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	Note 1
ASBESTOS-ST2-10/2/07	030732863-0002	Southeast Area (sidewalk bridge level)	10/2/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST4-10/2/07	030732863-0003	Northwest Area (street-level)	10/2/07	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST5-10/2/07	030732863-0004	Firehouse #10 (roof level)	10/2/07	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST10-10/2/07	030732863-0005	North Side Sidewalk Bridge	10/2/07	1	2.880	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST11-10/2/07	030732863-0006	90 Trinity Place (roof level)	10/2/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST12-10/2/07	030732863-0007	110 Greenwich Street (roof level)	10/2/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST13-10/2/07	030732863-0008	Marriott Hotel, 38th Floor (roof level)	10/2/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST14-10/2/07	030732863-0009	West Face - South end at corner (scaffolding level)	10/2/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST15-10/2/07	030732863-0010	South Face - East end at corner (scaffolding level)	10/2/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST16-10/2/07	030732863-0011	East Face - North end at corner (scaffolding level)	10/2/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	
ASBESTOS-ST17-10/2/07	030732863-0012	North Face - West end at corner (scaffolding level)	10/2/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/07	< 13.00	No	No	

Note:

1. Due to flow rate RPD exceedance (50%) for asbestos at Station 1 (Southwest Area [sidewalk bridge level]) on October 2, 2007, the sample volume and subsequent sample result are estimated.