

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
<b>Target Air Quality Levels</b>										NA			
<b>EPA Site Specific Trigger Levels</b>										70			
ASBESTOS-ST1-10/06/07	030733247-0001	Southwest Area (sidewalk bridge level)	10/6/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST2-10/06/07	030733247-0002	Southeast Area (sidewalk bridge level)	10/6/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST4-10/06/07	030733247-0003	Northwest Area (street-level)	10/6/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST5-10/06/07	030733247-0004	Firehouse #10 (roof level)	10/6/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST10-10/06/07	030733247-0005	North Side Sidewalk Bridge	10/6/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST11-10/06/07	030733247-0006	90 Trinity Place (roof level)	10/6/07	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST12-10/06/07	030733247-0007	110 Greenwich Street (roof level)	10/6/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST13-10/06/07	030733247-0008	Marriott Hotel, 38th Floor (roof level)	10/6/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST14-10/06/07	030733247-0009	West Face - South end at corner (scaffolding level)	10/6/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST15-10/06/07	030733247-0010	South Face - East end at corner (scaffolding level)	10/6/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST16-10/06/07	030733247-0011	East Face - North end at corner (scaffolding level)	10/6/07	1	2.910	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST17-10/06/07	030733247-0012	North Face - West end at corner (scaffolding level)	10/6/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST1-10/07/07	030733250-0001	Southwest Area (sidewalk bridge level)	10/7/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 15.00	No	No	
ASBESTOS-ST2-10/07/07	030733250-0002	Southeast Area (sidewalk bridge level)	10/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST4-10/07/07	030733250-0003	Northwest Area (street-level)	10/7/07	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 15.00	No	No	
ASBESTOS-ST5-10/07/07	030733250-0004	Firehouse #10 (roof level)	10/7/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 15.00	No	No	
ASBESTOS-ST10-10/07/07	030733250-0005	North Side Sidewalk Bridge	10/7/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 15.00	No	No	
ASBESTOS-ST11-10/07/07	030733250-0006	90 Trinity Place (roof level)	10/7/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST12-10/07/07	030733250-0007	110 Greenwich Street (roof level)	10/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST13-10/07/07	030733250-0008	Marriott Hotel, 38th Floor (roof level)	10/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST14-10/07/07	030733250-0009	West Face - South end at corner (scaffolding level)	10/7/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST15-10/07/07	030733250-0010	South Face - East end at corner (scaffolding level)	10/7/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	
ASBESTOS-ST16-10/07/07	030733250-0011	East Face - North end at corner (scaffolding level)	10/7/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 15.00	No	No	
ASBESTOS-ST17-10/07/07	030733250-0012	North Face - West end at corner (scaffolding level)	10/7/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/07	< 13.00	No	No	