

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										NA			
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-10/11/08	030836209-0001	Southwest Area (sidewalk bridge level)	10/11/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST2-10/11/08	030836209-0002	Southeast Area (sidewalk bridge level)	10/11/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST4-10/11/08	030836209-0003	Northwest Area (street-level)	10/11/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST5-10/11/08	030836209-0004	Firehouse #10 (roof level)	10/11/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST10-10/11/08	030836209-0005	North Side Sidewalk Bridge	10/11/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST11-10/11/08	030836209-0006	90 Trinity Place (roof level)	10/11/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST12-10/11/08	030836209-0007	110 Greenwich Street (roof level)	10/11/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST13-10/11/08	030836209-0008	Marriott Hotel, 38th Floor (roof level)	10/11/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST14-10/11/08	030836209-0009	West Face - South end at corner (scaffolding level)	10/11/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST15-10/11/08	030836209-0010	South Face - East end at corner (scaffolding level)	10/11/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST16-10/11/08	030836209-0011	East Face - North end at corner (scaffolding level)	10/11/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST17-10/11/08	030836209-0012	North Face - West end at corner (scaffolding level)	10/11/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST1-10/12/08	030836211-0001	Southwest Area (sidewalk bridge level)	10/12/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST2-10/12/08	030836211-0002	Southeast Area (sidewalk bridge level)	10/12/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST4-10/12/08	030836211-0003	Northwest Area (street-level)	10/12/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST5-10/12/08	030836211-0004	Firehouse #10 (roof level)	10/12/08	1	3.220	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST10-10/12/08	030836211-0005	North Side Sidewalk Bridge	10/12/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST11-10/12/08	030836211-0006	90 Trinity Place (roof level)	10/12/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST12-10/12/08	030836211-0007	110 Greenwich Street (roof level)	10/12/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST13-10/12/08	030836211-0008	Marriott Hotel, 38th Floor (roof level)	10/12/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 13.00	No	No	
ASBESTOS-ST14-10/12/08	030836211-0009	West Face - South end at corner (scaffolding level)	10/12/08	1	3.320	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST15-10/12/08	030836211-0010	South Face - East end at corner (scaffolding level)	10/12/08	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST16-10/12/08	030836211-0011	East Face - North end at corner (scaffolding level)	10/12/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	
ASBESTOS-ST17-10/12/08	030836211-0012	North Face - West end at corner (scaffolding level)	10/12/08	1	3.300	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/13/08	< 15.00	No	No	