

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										NA			
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-10/14/09	030926330-0001	Southwest Area (sidewalk bridge level)	10/14/09	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/09	< 13.00	No	No	
ASBESTOS-ST2-10/14/09	030926330-0002	Southeast Area (sidewalk bridge level)	10/14/09	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/09	< 13.00	No	No	
ASBESTOS-ST4-10/14/09	030926330-0003	Northwest Area (street-level)	10/14/09	1	3.270	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/09	< 13.00	No	No	
ASBESTOS-ST5-10/14/09	030926330-0004	Firehouse #10 (roof level)	10/14/09	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/09	< 13.00	No	No	
ASBESTOS-ST10-10/14/09	030926330-0005	North Side Sidewalk Bridge	10/14/09	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/09	< 13.00	No	No	
ASBESTOS-ST11-10/14/09	030926330-0006	90 Trinity Place (roof level)	10/14/09	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/09	< 13.00	No	No	
ASBESTOS-ST12-10/14/09	030926330-0007	110 Greenwich Street (roof level)	10/14/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/09	< 13.00	No	No	
ASBESTOS-ST13-10/14/09	030926330-0008	Marriott Hotel, 38th Floor (roof level)	10/14/09	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/09	< 13.00	No	No	
ASBESTOS-ST1-10/15/09	030926408-0001	Southwest Area (sidewalk bridge level)	10/15/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/09	< 13.00	No	No	
ASBESTOS-ST2-10/15/09	030926408-0002	Southeast Area (sidewalk bridge level)	10/15/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/09	< 13.00	No	No	
ASBESTOS-ST4-10/15/09	030926408-0003	Northwest Area (street-level)	10/15/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/09	< 13.00	No	No	
ASBESTOS-ST5-10/15/09	030926408-0004	Firehouse #10 (roof level)	10/15/09	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/09	< 15.00	No	No	
ASBESTOS-ST10-10/15/09	030926408-0005	North Side Sidewalk Bridge	10/15/09	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/09	< 13.00	No	No	
ASBESTOS-ST11-10/15/09	030926408-0006	90 Trinity Place (roof level)	10/15/09	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/09	< 15.00	No	No	
ASBESTOS-ST12-10/15/09	030926408-0007	110 Greenwich Street (roof level)	10/15/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/09	< 13.00	No	No	
ASBESTOS-ST13-10/15/09	030926408-0008	Marriott Hotel, 38th Floor (roof level)	10/15/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/09	< 13.00	No	No	
ASBESTOS-ST1-10/16/09	030926509-0001	Southwest Area (sidewalk bridge level)	10/16/09	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/09	< 13.00	No	No	
ASBESTOS-ST2-10/16/09	030926509-0002	Southeast Area (sidewalk bridge level)	10/16/09	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/09	< 13.00	No	No	
ASBESTOS-ST4-10/16/09	030926509-0003	Northwest Area (street-level)	10/16/09	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/09	< 13.00	No	No	
ASBESTOS-ST5-10/16/09	030926509-0004	Firehouse #10 (roof level)	10/16/09	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/09	< 15.00	No	No	
ASBESTOS-ST10-10/16/09	030926509-0005	North Side Sidewalk Bridge	10/16/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/09	< 13.00	No	No	
ASBESTOS-ST11-10/16/09	030926509-0006	90 Trinity Place (roof level)	10/16/09	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/09	< 13.00	No	No	
ASBESTOS-ST12-10/16/09	030926509-0007	110 Greenwich Street (roof level)	10/16/09	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/09	< 13.00	No	No	
ASBESTOS-ST13-10/16/09	030926509-0008	Marriott Hotel, 38th Floor (roof level)	10/16/09	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/09	< 13.00	No	No	

Note:

1. Asbestos sample results are not available on October 17, 2009 since no sampling was conducted on this day due to the lack of work activities. This is in accordance with Amendment #9 to the September 2005 Ambient Air Monitoring Program Plan.