

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-10/17/06	030634160-0001	Southwest Area (sidewalk bridge level)	10/17/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST2-10/17/06	030634160-0002	Southeast Area (sidewalk bridge level)	10/17/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST4-10/17/06	030634160-0003	Northwest Area (street-level)	10/17/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST5-10/17/06	030634160-0004	Firehouse #10 (roof level)	10/17/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST10-10/17/06	030634160-0005	North Side Sidewalk Bridge	10/17/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST11-10/17/06	030634160-0006	90 Trinity Place (roof level)	10/17/06	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST12-10/17/06	030634160-0007	110 Greenwich Street (roof level)	10/17/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST13-10/17/06	030634160-0008	Marriott Hotel, 38th Floor (roof level)	10/17/06	1	2.710	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 11.00	No	No	Note 1.	
ASBESTOS-ST14-10/17/06	030634160-0009	West Face - South end at corner (scaffolding level)	10/17/06	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST15-10/17/06	030634160-0010	South Face - East end at corner (scaffolding level)	10/17/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST16-10/17/06	030634160-0011	East Face - North end at corner (scaffolding level)	10/17/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST17-10/17/06	030634160-0012	North Face - West end at corner (scaffolding level)	10/17/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/06	< 13.00	No	No		
ASBESTOS-ST1-10/18/06	030634305-0001	Southwest Area (sidewalk bridge level)	10/18/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST2-10/18/06	030634305-0002	Southeast Area (sidewalk bridge level)	10/18/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST4-10/18/06	030634305-0003	Northwest Area (street-level)	10/18/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST5-10/18/06	030634305-0004	Firehouse #10 (roof level)	10/18/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST10-10/18/06	030634305-0005	North Side Sidewalk Bridge	10/18/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST11-10/18/06	030634305-0006	90 Trinity Place (roof level)	10/18/06	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST12-10/18/06	030634305-0007	110 Greenwich Street (roof level)	10/18/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST13-10/18/06	030634305-0008	Marriott Hotel, 38th Floor (roof level)	10/18/06	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST14-10/18/06	030634305-0009	West Face - South end at corner (scaffolding level)	10/18/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST15-10/18/06	030634305-0010	South Face - East end at corner (scaffolding level)	10/18/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST16-10/18/06	030634305-0011	East Face - North end at corner (scaffolding level)	10/18/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		
ASBESTOS-ST17-10/18/06	030634305-0012	North Face - West end at corner (scaffolding level)	10/18/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/19/06	< 13.00	No	No		

Note:

1. Due to a flow rate RPD exceedance (23.3%) for asbestos at Station 13 (Marriott Hotel, 38th Floor [roof level]) on October 17, 2006, the sample volume and subsequent sample result are estimated.