

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA			
										70			
ASBESTOS-ST1-10/19/06	030634439-0001	Southwest Area (sidewalk bridge level)	10/19/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST2-10/19/06	030634439-0002	Southeast Area (sidewalk bridge level)	10/19/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST4-10/19/06	030634439-0003	Northwest Area (street-level)	10/19/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST5-10/19/06	030634439-0004	Firehouse #10 (roof level)	10/19/06	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST10-10/19/06	030634439-0005	North Side Sidewalk Bridge	10/19/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST11-10/19/06	030634439-0006	90 Trinity Place (roof level)	10/19/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST12-10/19/06	030634439-0007	110 Greenwich Street (roof level)	10/19/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST13-10/19/06	030634439-0008	Marriott Hotel, 38th Floor (roof level)	10/19/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST14-10/19/06	030634439-0009	West Face - South end at corner (scaffolding level)	10/19/06	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST15-10/19/06	030634439-0010	South Face - East end at corner (scaffolding level)	10/19/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST16-10/19/06	030634439-0011	East Face - North end at corner (scaffolding level)	10/19/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	
ASBESTOS-ST17-10/19/06	030634439-0012	North Face - West end at corner (scaffolding level)	10/19/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/20/06	< 13.00	No	No	