

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels											Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels													
											NA		
											70		
ASBESTOS-ST1-10/21/08	030837503-0001	Southwest Area (sidewalk bridge level)	10/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST2-10/21/08	030837503-0002	Southeast Area (sidewalk bridge level)	10/21/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST4-10/21/08	030837503-0003	Northwest Area (street-level)	10/21/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST5-10/21/08	030837503-0004	Firehouse #10 (roof level)	10/21/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST10-10/21/08	030837503-0005	North Side Sidewalk Bridge	10/21/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST11-10/21/08	030837503-0006	90 Trinity Place (roof level)	10/21/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST12-10/21/08	030837503-0007	110 Greenwich Street (roof level)	10/21/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST13-10/21/08	030837503-0008	Marriott Hotel, 38th Floor (roof level)	10/21/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST14-10/21/08	030837503-0009	West Face - South end at corner (scaffolding level)	10/21/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST15-10/21/08	030837503-0010	South Face - East end at corner (scaffolding level)	10/21/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST16-10/21/08	030837503-0011	East Face - North end at corner (scaffolding level)	10/21/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	
ASBESTOS-ST17-10/21/08	030837503-0012	North Face - West end at corner (scaffolding level)	10/21/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/22/08	< 13.00	No	No	