

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA				
										70				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ABSESTOS-ST1-10/27/07	030735036-0001	Southwest Area (sidewalk bridge level)	10/27/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST2-10/27/07	030735036-0002	Southeast Area (sidewalk bridge level)	10/27/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST4-10/27/07	030735036-0003	Northwest Area (street-level)	10/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST5-10/27/07	030735036-0004	Firehouse #10 (roof level)	10/27/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST10-10/27/07	030735036-0005	North Side Sidewalk Bridge	10/27/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST11-10/27/07	030735036-0006	90 Trinity Place (roof level)	10/27/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST12-10/27/07	030735036-0007	110 Greenwich Street (roof level)	10/27/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST13-10/27/07	030735036-0008	Marriott Hotel, 38th Floor (roof level)	10/27/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST14-10/27/07	030735036-0009	West Face - South end at corner (scaffolding level)	10/27/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST15-10/27/07	030735036-0010	South Face - East end at corner (scaffolding level)	10/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST16-10/27/07	030735036-0011	East Face - North end at corner (scaffolding level)	10/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ABSESTOS-ST17-10/27/07	030735036-0012	North Face - West end at corner (scaffolding level)	10/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/07	< 13.00		No	No	
ASBESTOS-ST1-10/28/07	030735092-0001	Southwest Area (sidewalk bridge level)	10/28/07	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST2-10/28/07	030735092-0002	Southeast Area (sidewalk bridge level)	10/28/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST4-10/28/07	030735092-0003	Northwest Area (street-level)	10/28/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST5-10/28/07	030735092-0004	Firehouse #10 (roof level)	10/28/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST10-10/28/07	030735092-0005	North Side Sidewalk Bridge	10/28/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST11-10/28/07	030735092-0006	90 Trinity Place (roof level)	10/28/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST12-10/28/07	030735092-0007	110 Greenwich Street (roof level)	10/28/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST13-10/28/07	030735092-0008	Marriott Hotel, 38th Floor (roof level)	10/28/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST14-10/28/07	030735092-0009	West Face - South end at corner (scaffolding level)	10/28/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST15-10/28/07	030735092-0010	South Face - East end at corner (scaffolding level)	10/28/07	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST16-10/28/07	030735092-0011	East Face - North end at corner (scaffolding level)	10/28/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	
ASBESTOS-ST17-10/28/07	030735092-0012	North Face - West end at corner (scaffolding level)	10/28/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/07	< 13.00		No	No	