

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels											70	Levels	Trigger Levels	
ASBESTOS-ST1-10/31/08	030838864-0001	Southwest Area (sidewalk bridge level)	10/31/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 15.00	No	No		
ASBESTOS-ST2-10/31/08	030838864-0002	Southeast Area (sidewalk bridge level)	10/31/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 13.00	No	No		
ASBESTOS-ST4-10/31/08	030838864-0003	Northwest Area (street-level)	10/31/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 15.00	No	No		
ASBESTOS-ST5-10/31/08	030838864-0004	Firehouse #10 (roof level)	10/31/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 15.00	No	No		
ASBESTOS-ST10-10/31/08	030838864-0005	North Side Sidewalk Bridge	10/31/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 13.00	No	No		
ASBESTOS-ST11-10/31/08	030838864-0006	90 Trinity Place (roof level)	10/31/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 13.00	No	No		
ASBESTOS-ST12-10/31/08	030838864-0007	110 Greenwich Street (roof level)	10/31/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 13.00	No	No		
ASBESTOS-ST13-10/31/08	030838864-0008	Marriott Hotel, 38th Floor (roof level)	10/31/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 15.00	No	No		
ASBESTOS-ST14-10/31/08	030838864-0009	West Face - South end at corner (scaffolding level)	10/31/08	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 13.00	No	No		
ASBESTOS-ST15-10/31/08	030838864-0010	South Face - East end at corner (scaffolding level)	10/31/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 13.00	No	No		
ASBESTOS-ST16-10/31/08	030838864-0011	East Face - North end at corner (scaffolding level)	10/31/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 13.00	No	No		
ASBESTOS-ST17-10/31/08	030838864-0012	North Face - West end at corner (scaffolding level)	10/31/08	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/1/08	< 13.00	No	No		
ASBESTOS-ST1-11/1/08	030839077-0001	Southwest Area (sidewalk bridge level)	11/1/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST2-11/1/08	030839077-0002	Southeast Area (sidewalk bridge level)	11/1/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST4-11/1/08	030839077-0003	Northwest Area (street-level)	11/1/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST5-11/1/08	030839077-0004	Firehouse #10 (roof level)	11/1/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST10-11/1/08	030839077-0005	North Side Sidewalk Bridge	11/1/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST11-11/1/08	030839077-0006	90 Trinity Place (roof level)	11/1/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST12-11/1/08	030839077-0007	110 Greenwich Street (roof level)	11/1/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST13-11/1/08	030839077-0008	Marriott Hotel, 38th Floor (roof level)	11/1/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST14-11/1/08	030839077-0009	West Face - South end at corner (scaffolding level)	11/1/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST15-11/1/08	030839077-0010	South Face - East end at corner (scaffolding level)	11/1/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST16-11/1/08	030839077-0011	East Face - North end at corner (scaffolding level)	11/1/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST17-11/1/08	030839077-0012	North Face - West end at corner (scaffolding level)	11/1/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST1-11/2/08	030839078-0001	Southwest Area (sidewalk bridge level)	11/2/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 13.00	No	No		
ASBESTOS-ST2-11/2/08	030839078-0002	Southeast Area (sidewalk bridge level)	11/2/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 13.00	No	No		
ASBESTOS-ST4-11/2/08	030839078-0003	Northwest Area (street-level)	11/2/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 13.00	No	No		
ASBESTOS-ST5-11/2/08	030839078-0004	Firehouse #10 (roof level)	11/2/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 13.00	No	No		
ASBESTOS-ST10-11/2/08	030839078-0005	North Side Sidewalk Bridge	11/2/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST11-11/2/08	030839078-0006	90 Trinity Place (roof level)	11/2/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST12-11/2/08	030839078-0007	110 Greenwich Street (roof level)	11/2/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST13-11/2/08	030839078-0008	Marriott Hotel, 38th Floor (roof level)	11/2/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 13.00	No	No		
ASBESTOS-ST14-11/2/08	030839078-0009	West Face - South end at corner (scaffolding level)	11/2/08	1	3.220	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST15-11/2/08	030839078-0010	South Face - East end at corner (scaffolding level)	11/2/08	1	3.290	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST16-11/2/08	030839078-0011	East Face - North end at corner (scaffolding level)	11/2/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		
ASBESTOS-ST17-11/2/08	030839078-0012	North Face - West end at corner (scaffolding level)	11/2/08	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/08	< 15.00	No	No		