

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels											Air Quality Levels	Site Specific Trigger Levels	Comments
EPA Site Specific Trigger Levels													
											NA		
											70		
ASBESTOS-ST1-11/6/07	030736001-0001	Southwest Area (sidewalk bridge level)	11/6/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	
ASBESTOS-ST2-11/6/07	030736001-0002	Southeast Area (sidewalk bridge level)	11/6/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	
ASBESTOS-ST4-11/6/07	030736001-0003	Northwest Area (street-level)	11/6/07	1	2.710	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	Note 1
ASBESTOS-ST5-11/6/07	030736001-0004	Firehouse #10 (roof level)	11/6/07	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 15.00	No	No	
ASBESTOS-ST10-11/6/07	030736001-0005	North Side Sidewalk Bridge	11/6/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	
ASBESTOS-ST11-11/6/07	030736001-0006	90 Trinity Place (roof level)	11/6/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	
ASBESTOS-ST12-11/6/07	030736001-0007	110 Greenwich Street (roof level)	11/6/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	
ASBESTOS-ST13-11/6/07	030736001-0008	Marriott Hotel, 38th Floor (roof level)	11/6/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 15.00	No	No	
ASBESTOS-ST14-11/6/07	030736001-0009	West Face - South end at corner (scaffolding level)	11/6/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	
ASBESTOS-ST15-11/6/07	030736001-0010	South Face - East end at corner (scaffolding level)	11/6/07	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 15.00	No	No	
ASBESTOS-ST16-11/6/07	030736001-0011	East Face - North end at corner (scaffolding level)	11/6/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	
ASBESTOS-ST17-11/6/07	030736001-0012	North Face - West end at corner (scaffolding level)	11/6/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/7/07	< 13.00	No	No	
ASBESTOS-ST1-11/7/07	030736095-0001	Southwest Area (sidewalk bridge level)	11/7/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST2-11-7-07	030736095-0002	Southeast Area (sidewalk bridge level)	11/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST4-11/7/07	030736095-0003	Northwest Area (street-level)	11/7/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST5-11/7/07	030736095-0004	Firehouse #10 (roof level)	11/7/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST10-11/7/07	030736095-0005	North Side Sidewalk Bridge	11/7/07	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST11-11/7/07	030736095-0006	90 Trinity Place (roof level)	11/7/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST13-11/7/07	030736095-0007	Marriott Hotel, 38th Floor (roof level)	11/7/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST14-11/7/07	030736095-0008	West Face - South end at corner (scaffolding level)	11/7/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST15-11/7/07	030736095-0009	South Face - East end at corner (scaffolding level)	11/7/07	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 15.00	No	No	
ASBESTOS-ST16-11/7/07	030736095-0010	East Face - North end at corner (scaffolding level)	11/7/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST17-11/7/07	030736095-0011	North Face - West end at corner (scaffolding level)	11/7/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/07	< 13.00	No	No	
ASBESTOS-ST1-11/8/07	030736197-0001	Southwest Area (sidewalk bridge level)	11/8/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST2-11/8/07	030736197-0002	Southeast Area (sidewalk bridge level)	11/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST4-11/8/07	030736197-0003	Northwest Area (street-level)	11/8/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST5-11/8/07	030736197-0004	Firehouse #10 (roof level)	11/8/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST10-11/8/07	030736197-0005	North Side Sidewalk Bridge	11/8/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST11-11/8/07	030736197-0006	90 Trinity Place (roof level)	11/8/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST12-11/8/07	030736197-0007	110 Greenwich Street (roof level)	11/8/07	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST13-11/8/07	030736197-0008	Marriott Hotel, 38th Floor (roof level)	11/8/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST14-11/8/07	030736197-0009	West Face - South end at corner (scaffolding level)	11/8/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST15-11/8/07	030736197-0010	South Face - East end at corner (scaffolding level)	11/8/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST16-11/8/07	030736197-0011	East Face - North end at corner (scaffolding level)	11/8/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST17-11/8/07	030736197-0012	North Face - West end at corner (scaffolding level)	11/8/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/9/07	< 13.00	No	No	
ASBESTOS-ST1-11/9/07	030736289-0001	Southwest Area (sidewalk bridge level)	11/9/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST2-11/9/07	030736289-0002	Southeast Area (sidewalk bridge level)	11/9/07	1	2.910	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST4-11/9/07	030736289-0003	Northwest Area (street-level)	11/9/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST5-11/9/07	030736289-0004	Firehouse #10 (roof level)	11/9/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST10-11/9/07	030736289-0005	North Side Sidewalk Bridge	11/9/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST11-11/9/07	030736289-0006	90 Trinity Place (roof level)	11/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST12-11/9/07	030736289-0007	110 Greenwich Street (roof level)	11/9/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST13-11/9/07	030736289-0008	Marriott Hotel, 38th Floor (roof level)	11/9/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST14-11/9/07	030736289-0009	West Face - South end at corner (scaffolding level)	11/9/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST15-11/9/07	030736289-0010	South Face - East end at corner (scaffolding level)	11/9/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST16-11/9/07	030736289-0011	East Face - North end at corner (scaffolding level)	11/9/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	
ASBESTOS-ST17-11/9/07	030736289-0012	North Face - West end at corner (scaffolding level)	11/9/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/10/07	< 13.00	No	No	

Note:

1. Due to flow rate RPD exceedance (23.3%) for asbestos at Station 4 (Northwest Area [street-level]) on November 6, 2007, the sample volume and subsequent sample result are estimated.
2. Asbestos sample at Station 12 (110 Greenwich Street [roof level]) on November 7, 2007 was not available for analysis on account of power failure.