

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA			
										70			
ASBESTOS-ST1-11/23/05	030535533-0001	Southwest Area (sidewalk bridge level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST2-11/23/05	030535533-0002	Southeast Area (sidewalk bridge level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST4-11/23/05	030535533-0003	Northwest Area (street-level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST5-11/23/05	030535533-0004	Firehouse #10 (roof level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST10-11/23/05	030535533-0005	North Side Sidewalk Bridge	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST11-11/23/05	030535533-0006	90 Trinity Place (roof level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST12-11/23/05	030535533-0007	110 Greenwich Street (roof level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST13-11/23/05	030535533-0008	Marriott Hotel, 38th Floor (roof level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST14-11/23/05	030535533-0009	West Face - South end at corner (scaffolding level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST15-11/23/05	030535533-0010	South Face - East end at corner (scaffolding level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST16-11/23/05	030535533-0011	East Face - North end at corner (scaffolding level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	
ASBESTOS-ST17-11/23/05	030535533-0012	North Face - West end at corner (scaffolding level)	11/23/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/05	< 13.00	No	No	