

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-11/26/07	030737461-0001	Southwest Area (sidewalk bridge level)	11/26/07	1	3.220	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 15.00	No	No		
ASBESTOS-ST2-11/26/07	030737461-0002	Southeast Area (sidewalk bridge level)	11/26/07	1	2.840	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 13.00	No	No		
ASBESTOS-ST4-11/26/07	030737461-0003	Northwest Area (street-level)	11/26/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 13.00	No	No		
ASBESTOS-ST5-11/26/07	030737461-0004	Firehouse #10 (roof level)	11/26/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 15.00	No	No		
ASBESTOS-ST10-11/26/07	030737461-0005	North Side Sidewalk Bridge	11/26/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 15.00	No	No		
ASBESTOS-ST11-11/26/07	030737461-0006	90 Trinity Place (roof level)	11/26/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 15.00	No	No		
ASBESTOS-ST12-11/26/07	030737461-0007	110 Greenwich Street (roof level)	11/26/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 15.00	No	No		
ASBESTOS-ST13-11/26/07	030737461-0008	Marriott Hotel, 38th Floor (roof level)	11/26/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 15.00	No	No		
ASBESTOS-ST14-11/26/07	030737461-0009	West Face - South end at corner (scaffolding level)	11/26/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 15.00	No	No		
ASBESTOS-ST15-11/26/07	030737461-0010	South Face - East end at corner (scaffolding level)	11/26/07	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 15.00	No	No		
ASBESTOS-ST16-11/26/07	030737461-0011	East Face - North end at corner (scaffolding level)	11/26/07	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 13.00	No	No		
ASBESTOS-ST17-11/26/07	030737461-0012	North Face - West end at corner (scaffolding level)	11/26/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/27/07	< 13.00	No	No		
ASBESTOS-ST1-11/27/07	030737551-0001	Southwest Area (sidewalk bridge level)	11/27/07	1	2.880	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST2-11/27/07	030737551-0002	Southeast Area (sidewalk bridge level)	11/27/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST4-11/27/07	030737551-0003	Northwest Area (street-level)	11/27/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST5-11/27/07	030737551-0004	Firehouse #10 (roof level)	11/27/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	13.00	No	No		
ASBESTOS-ST10-11/27/07	030737551-0005	North Side Sidewalk Bridge	11/27/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST11-11/27/07	030737551-0006	90 Trinity Place (roof level)	11/27/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST12-11/27/07	030737551-0007	110 Greenwich Street (roof level)	11/27/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST13-11/27/07	030737551-0008	Marriott Hotel, 38th Floor (roof level)	11/27/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST14-11/27/07	030737551-0009	West Face - South end at corner (scaffolding level)	11/27/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST15-11/27/07	030737551-0010	South Face - East end at corner (scaffolding level)	11/27/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST16-11/27/07	030737551-0011	East Face - North end at corner (scaffolding level)	11/27/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No		
ASBESTOS-ST17-11/27/07	030737551-0012	North Face - West end at corner (scaffolding level)	11/27/07	1	3.530	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/07	< 13.00	No	No	Note 1	
ABESTOS-ST1-11/28/07	030737651-0001	Southwest Area (sidewalk bridge level)	11/28/07	1	2.840	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST2-11/28/07	030737651-0002	Southeast Area (sidewalk bridge level)	11/28/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST4-11/28/07	030737651-0003	Northwest Area (street-level)	11/28/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST5-11/28/07	030737651-0004	Firehouse #10 (roof level)	11/28/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST10-11/28/07	030737651-0005	North Side Sidewalk Bridge	11/28/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST11-11/28/07	030737651-0006	90 Trinity Place (roof level)	11/28/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST12-11/28/07	030737651-0007	110 Greenwich Street (roof level)	11/28/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST13-11/28/07	030737651-0008	Marriott Hotel, 38th Floor (roof level)	11/28/07	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST14-11/28/07	030737651-0009	West Face - South end at corner (scaffolding level)	11/28/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST15-11/28/07	030737651-0010	South Face - East end at corner (scaffolding level)	11/28/07	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST16-11/28/07	030737651-0011	East Face - North end at corner (scaffolding level)	11/28/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST17-11/28/07	030737651-0012	North Face - West end at corner (scaffolding level)	11/28/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		
ABESTOS-ST100-11/28/07	030737651-0013	Station 10 Field Duplicate	11/28/07	1	3.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/07	< 13.00	No	No		

Note:
1. Due to flow rate RPD exceedance (28.6%) for asbestos at Station 17 (North Face - West end at corner [scaffolding level]) on November 27, 2007, the sample volume and subsequent sample result are estimated.