

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-11/29/06	030638774-0001	Southwest Area (sidewalk bridge level)	11/29/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST2-11/29/06	030638774-0002	Southeast Area (sidewalk bridge level)	11/29/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST4-11/29/06	030638774-0003	Northwest Area (street-level)	11/29/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST5-11/29/06	030638774-0004	Firehouse #10 (roof level)	11/29/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST10-11/29/06	030638774-0005	North Side Sidewalk Bridge	11/29/06	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST11-11/29/06	030638774-0006	90 Trinity Place (roof level)	11/29/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST12-11/29/06	030638774-0007	110 Greenwich Street (roof level)	11/29/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST13-11/29/06	030638774-0008	Marriott Hotel, 38th Floor (roof level)	11/29/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST14-11/29/06	030638774-0009	West Face - South end at corner (scaffolding level)	11/29/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST15-11/29/06	030638774-0010	South Face - East end at corner (scaffolding level)	11/29/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST16-11/29/06	030638774-0011	East Face - North end at corner (scaffolding level)	11/29/06	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST17-11/29/06	030638774-0012	North Face - West end at corner (scaffolding level)	11/29/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/30/06	< 13.00	No	No		
ASBESTOS-ST1-11/30/06	030638918-0001	Southwest Area (sidewalk bridge level)	11/30/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST2-11/30/06	030638918-0002	Southeast Area (sidewalk bridge level)	11/30/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST4-11/30/06	030638918-0003	Northwest Area (street-level)	11/30/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST5-11/30/06	030638918-0004	Firehouse #10 (roof level)	11/30/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST10-11/30/06	030638918-0005	North Side Sidewalk Bridge	11/30/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST11-11/30/06	030638918-0006	90 Trinity Place (roof level)	11/30/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST12-11/30/06	030638918-0007	110 Greenwich Street (roof level)	11/30/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST13-11/30/06	030638918-0008	Marriott Hotel, 38th Floor (roof level)	11/30/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST14-11/30/06	030638918-0009	West Face - South end at corner (scaffolding level)	11/30/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST15-11/30/06	030638918-0010	South Face - East end at corner (scaffolding level)	11/30/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST16-11/30/06	030638918-0011	East Face - North end at corner (scaffolding level)	11/30/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		
ASBESTOS-ST17-11/30/06	030638918-0012	North Face - West end at corner (scaffolding level)	11/30/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/06	< 13.00	No	No		