

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
<b>Target Air Quality Levels</b>										NA			
<b>EPA Site Specific Trigger Levels</b>										70			
ASBESTOS-ST1-11/29/08	030842199-0001	Southwest Area (sidewalk bridge level)	11/29/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST2-11/29/08	030842199-0002	Southeast Area (sidewalk bridge level)	11/29/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST4-11/29/08	030842199-0003	Northwest Area (street-level)	11/29/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST5-11/29/08	030842199-0004	Firehouse #10 (roof level)	11/29/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST10-11/29/08	030842199-0005	North Side Sidewalk Bridge	11/29/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST11-11/29/08	030842199-0006	90 Trinity Place (roof level)	11/29/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST12-11/29/08	030842199-0007	110 Greenwich Street (roof level)	11/29/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST13-11/29/08	030842199-0008	Marriott Hotel, 38th Floor (roof level)	11/29/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST14-11/29/08	030842199-0009	West Face - South end at corner (scaffolding level)	11/29/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST15-11/29/08	030842199-0010	South Face - East end at corner (scaffolding level)	11/29/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST16-11/29/08	030842199-0011	East Face - North end at corner (scaffolding level)	11/29/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST17-11/29/08	030842199-0012	North Face - West end at corner (scaffolding level)	11/29/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST1-11/30/08	030842206-0001	Southwest Area (sidewalk bridge level)	11/30/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST2-11/30/08	030842206-0002	Southeast Area (sidewalk bridge level)	11/30/08	1	3.220	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST4-11/30/08	030842206-0003	Northwest Area (street-level)	11/30/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST5-11/30/08	030842206-0004	Firehouse #10 (roof level)	11/30/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST10-11/30/08	030842206-0005	North Side Sidewalk Bridge	11/30/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST11-11/30/08	030842206-0006	90 Trinity Place (roof level)	11/30/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST12-11/30/08	030842206-0007	110 Greenwich Street (roof level)	11/30/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST13-11/30/08	030842206-0008	Marriott Hotel, 38th Floor (roof level)	11/30/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST14-11/30/08	030842206-0009	West Face - South end at corner (scaffolding level)	11/30/08	1	3.260	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST15-11/30/08	030842206-0010	South Face - East end at corner (scaffolding level)	11/30/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST16-11/30/08	030842206-0011	East Face - North end at corner (scaffolding level)	11/30/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	
ASBESTOS-ST17-11/30/08	030842206-0012	North Face - West end at corner (scaffolding level)	11/30/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/1/08	< 13.00	No	No	