

| TRC Field Sample No. | Sample No. | Sampling Location | Collection Start Date | Work Shift | Sample Volume (m ³) | Analyte | Analytical Method | Lab | Lab Sample Receipt Date | Asbestos AHERA Concentration (S/mm2) | Exceeds Target | Exceeds EPA | Comments |
|-----------------------|----------------|---|-----------------------|------------|---------------------------------|----------|---------------------------------|------|-------------------------|--------------------------------------|--------------------|------------------------------|----------|
| | | | | | | | | | | NA | Air Quality Levels | Site Specific Trigger Levels | |
| | | | | | | | | | | 70 | | | |
| | | | | | | | | | | Target Air Quality Levels | | | |
| | | | | | | | | | | EPA Site Specific Trigger Levels | | | |
| ASBESTOS-ST1-12/1/07 | 030737927-0001 | Southwest Area (sidewalk bridge level) | 12/1/07 | 1 | 3.040 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 15.00 | No | No | |
| ASBESTOS-ST2-12/1/07 | 030737927-0002 | Southeast Area (sidewalk bridge level) | 12/1/07 | 1 | 3.110 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 15.00 | No | No | |
| ASBESTOS-ST4-12/1/07 | 030737927-0003 | Northwest Area (street-level) | 12/1/07 | 1 | 3.120 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 15.00 | No | No | |
| ASBESTOS-ST5-12/1/07 | 030737927-0004 | Firehouse #10 (roof level) | 12/1/07 | 1 | 2.920 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST10-12/1/07 | 030737927-0005 | North Side Sidewalk Bridge | 12/1/07 | 1 | 3.030 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST11-12/1/07 | 030737927-0006 | 90 Trinity Place (roof level) | 12/1/07 | 1 | 3.070 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 15.00 | No | No | |
| ASBESTOS-ST12-12/1/07 | 030737927-0007 | 110 Greenwich Street (roof level) | 12/1/07 | 1 | 3.020 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST13-12/1/07 | 030737927-0008 | Marriott Hotel, 38th Floor (roof level) | 12/1/07 | 1 | 3.020 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST14-12/1/07 | 030737927-0009 | West Face - South end at corner (scaffolding level) | 12/1/07 | 1 | 2.930 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST15-12/1/07 | 030737927-0010 | South Face - East end at corner (scaffolding level) | 12/1/07 | 1 | 3.040 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 15.00 | No | No | |
| ASBESTOS-ST16-12/1/07 | 030737927-0011 | East Face - North end at corner (scaffolding level) | 12/1/07 | 1 | 3.040 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 15.00 | No | No | |
| ASBESTOS-ST17-12/1/07 | 030737927-0012 | North Face - West end at corner (scaffolding level) | 12/1/07 | 1 | 3.160 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST1-12/2/07 | 030737926-0001 | Southwest Area (sidewalk bridge level) | 12/2/07 | 1 | 3.010 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST2-12/2/07 | 030737926-0002 | Southeast Area (sidewalk bridge level) | 12/2/07 | 1 | 3.000 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST4-12/2/07 | 030737926-0003 | Northwest Area (street-level) | 12/2/07 | 1 | 3.000 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST5-12/2/07 | 030737926-0004 | Firehouse #10 (roof level) | 12/2/07 | 1 | 2.890 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST10-12/2/07 | 030737926-0005 | North Side Sidewalk Bridge | 12/2/07 | 1 | 2.970 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST11-12/2/07 | 030737926-0006 | 90 Trinity Place (roof level) | 12/2/07 | 1 | 3.010 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST12-12/2/07 | 030737926-0007 | 110 Greenwich Street (roof level) | 12/2/07 | 1 | 3.000 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST13-12/2/07 | 030737926-0008 | Marriott Hotel, 38th Floor (roof level) | 12/2/07 | 1 | 3.020 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 13.00 | No | No | |
| ASBESTOS-ST14-12/2/07 | 030737926-0009 | West Face - South end at corner (scaffolding level) | 12/2/07 | 1 | 3.810 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 19.00 | No | No | |
| ASBESTOS-ST15-12/2/07 | 030737926-0010 | South Face - East end at corner (scaffolding level) | 12/2/07 | 1 | 3.930 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 19.00 | No | No | |
| ASBESTOS-ST16-12/2/07 | 030737926-0011 | East Face - North end at corner (scaffolding level) | 12/2/07 | 1 | 3.710 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 15.00 | No | No | |
| ASBESTOS-ST17-12/2/07 | 030737926-0012 | North Face - West end at corner (scaffolding level) | 12/2/07 | 1 | 3.620 | Asbestos | TEM EPA 40 CFR PART 763 (AHERA) | EMSL | 12/3/07 | < 15.00 | No | No | |